


CR72529

REPORT NO: 2390



DC POWER SUPPLY
FOR
BRAYTON CYCLE POWER CONVERSION SYSTEM

by
M. KRUSE



GULTON INDUSTRIES, INC.
Engineered Magnetics Division

FACILITY FORM 602	N70-36860	
	(ACCESSION NUMBER)	(THRU)
	152	(CODE)
	CR-72529	03
	(PAGES)	(CATEGORY)
	(NASA CR OR TMX OR AD NUMBER)	

Prepared For
NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

NASA Lewis Research Center
Contract NAS3-10936

Jack H. Shank, Project Manager

NOTICE

This report was prepared as an account of Government-sponsored work. Neither the United States, nor the National Aeronautics and Space Administration (NASA), nor any person acting on behalf of NASA:

- A.) Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately-owned rights; or
- B.) Assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method or process disclosed in this report.

As used above, "person acting on behalf of NASA" includes any employee or contractor of NASA, or employee of such contractor, to the extent that such employee or contractor of NASA or employee of such contractor prepares, disseminates, or provides access to any information pursuant to his employment or contract with NASA, or his employment with such contractor.

Requests for copies of this report should be referred to

National Aeronautics and Space Administration
Scientific and Technical Information Facility
P.O. Box 33
College Park, Md. 20740

CR72529

REPORT NO: 2390



DC POWER SUPPLY
FOR
BRAYTON CYCLE POWER CONVERSION SYSTEM

by
M. KRUSE

GULTON INDUSTRIES, INC.
Engineered Magnetics Division

Prepared For
NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

NASA Lewis Research Center
Contract NAS3-10936

Jack H. Shank, Project Manager

NOTICE

This report was prepared as an account of Government-sponsored work. Neither the United States, nor the National Aeronautics and Space Administration (NASA), nor any person acting on behalf of NASA:

- A.) Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately-owned rights; or
- B.) Assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method or process disclosed in this report.

As used above, "person acting on behalf of NASA" includes any employee or contractor of NASA, or employee of such contractor, to the extent that such employee or contractor of NASA or employee of such contractor prepares, disseminates, or provides access to any information pursuant to his employment or contract with NASA, or his employment with such contractor.

Requests for copies of this report should be referred to

National Aeronautics and Space Administration
Scientific and Technical Information Facility
P.O. Box 33
College Park, Md. 20740

CR-72529

REPORT NO. 2390

FINAL REPORT
DC POWER SUPPLY
ENGINEERED MAGNETICS MODEL EMPS252
FOR
BRAYTON CYCLE POWER CONVERSION SYSTEM

by
M. KRUSE

GULTON INDUSTRIES, INC.
Engineered Magnetics Division
13041 Cerise Avenue
Hawthorne, California

Prepared for
NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

AUGUST 27, 1970

CONTRACT NAS3-10936

NASA-LEWIS RESEARCH CENTER
CLEVELAND, OHIO

Jack H. Shank, Project Manager
Space Power Systems Division

FORWARD

This report describes work undertaken by the Engineered Magnetics Division of Gulton Industries for the NASA, Lewis Research Center under Contract NAS3-10936. The effort undertaken was the design, development, and testing of the DC Power Supply portion¹ of the Brayton cycle test engine which is under development at the Lewis Center. The report describes the work performed by Engineered Magnetics and the results of the described equipment development.

TABLE OF CONTENTS

	PAGE NO.
ABSTRACT	v
SUMMARY	1
I. INTRODUCTION	3
II. DESIGN DISCUSSION	9
A. POWER SUPPLY FUNCTION	9
B. POWER SUPPLY DESIGN	9
C. SYSTEM OPERATION	13
D. MECHANICAL DESIGN	21
III. POWER SUPPLY CIRCUIT DESCRIPTION	25
A. CONTROL LOGIC	25
B. TRANSFORMER-RECTIFIER AND BATTERY CHARGER	30
C. AMPERE HOUR METER	38
D. TELEMETRY	44
E. POWER RELAY	45
F. BATTERY SYSTEM	46
IV. RELIABILITY	47
V. TEST PLAN	50
VI. CONCLUSIONS	53
APPENDIX I. DRAWING PACKAGE	
APPENDIX II. TEST PROCEDURE AND OPERATION TEST DATA	
APPENDIX III. THERMAL TEST REPORT	

ABSTRACT

The Brayton DC Power Supply converts 1200 Hz AC power to positive 28 volt and negative 28 volt DC power for use in the Brayton Space Power System. This Supply also includes a positive and a negative 28 volt battery with chargers and control logic that directly supplies DC output power when AC input power is not available for conversion. The measured AC to DC conversion efficiency is 93%. The calculated Mean Time Between Failures is approximately 60,000 hours.

This report presents the theory of operation, electrical and mechanical design drawings, reliability calculations, parts selections, thermal measurements, and test results.

SUMMARY

The NASA Lewis Research Center is currently engaged in a Brayton Space Power Technology Program. The Brayton Power Conversion System (PCS) has applicability for solar, radioisotope, and nuclear space power systems. The Brayton system has a net output power range of 2.25 to 10.5 kW at 1200 Hz. The Brayton PCS is designed to operate unattended in space for five (5) years.

The DC Power Supply Program was conducted at Gulton Industries, Inc., Engineered Magnetics Division, under a contract with the NASA Lewis Research Center. This program included the design, development, fabrication, testing, and delivery of four DC Power Supplies.

A portion of the 1200 Hz Brayton PCS electrical output serves as an input to the DC Power Supply, which converts the AC power to DC power. Both positive and negative 28 VDC are furnished to the coolant pump static inverters and to the engine control system of the Brayton System. The DC Power Supply also includes positive and negative 28 volt batteries which will provide DC power when the AC input power is not available for conversion.

The DC Power Supply, which has a complete redundancy of its power conversion elements, requires only slight output filtering due to its advanced transformer configuration. It has a tested AC to DC conversion efficiency of 93%. The calculated Mean Time Between Failure of the DC Power Supply is 62,464 hours; with the use of Ultra-High Reliability components, Mean Time Between Failure exceeding the five-year system goal has been achieved.

The DC Power Supply theory of operation, electrical and mechanical design drawings, reliability calculations, parts selections, thermal measurements, and typical test results are presented in

this report.

The DC Power Supply meets or exceeds all requirements of the purchase specification with the exception of the Silver Cadmium batteries. The state-of-the-art in Silver Cadmium batteries was not compatible with the five (5) year life-objective of the Brayton program.

I. INTRODUCTION

This Final Report describes, in detail, the DC Power Supply Program conducted at Gulton Industries, Inc., Engineered Magnetics Division. The program for Engineered Magnetics Model EMPS252 DC Power Supply for the Brayton Cycle Power Conversion System (PCS) was initiated in August 1967.

The program objectives included design, development, fabrication, testing, and delivery of four DC Power Supply units to NASA-Lewis Research Center.

The primary function of the DC Power Supply of the Brayton Cycle Power Conversion System is to supply power to the DC bus during all operational conditions. When 208/120 volt, three phase, 1200 Hz power is available from the Brayton alternator, the DC Power Supply converts this AC power into the desired positive and negative 28 VDC to supply the DC bus. When the AC power is not available, the DC Power Supply provides power to the DC bus from the Silver Cadmium batteries which are part of the DC Power Supply. The design load on the DC bus is 1.5 kW. Engineered Magnetics Model EMPS252 DC Power Supply is completely self-contained, and includes provisions for external manual control of system functions.

The NASA contract defined the specific work requirements in four task groups, which were accomplished in the following sequence:

Task I - Preliminary Design Study.

During the Task I phase of the program, preliminary design and assembly details defining system parameters and design envelope for Engineered Magnetics Model EMPS252 DC Power Supply were accomplished, a satisfactory baseline was established, and a preliminary schematic drawing of the DC Power Supply was obtained. The DC Power Supply function and operation were defined. The Power Supply circuits were sectionalized as follows:

Logic
Transformer-Rectifier
Battery Charging
Ampere-Hour Meter
Telemetry
Power Relay
Battery

Operational characteristics and requirements for each of the above listed sections were established. The preliminary design of the DC Power Supply was defined. The circuits comprising the DC Power Supply were categorized as follows:

1. Logic Circuits

Transformer-Rectifier Output Sensing
Battery Discharge Sensing
Battery Overtemperature Protection
Battery Fullycharged Protection
Battery Disconnect From Ground Command

2. Transformer-Rectifier Power Supply

Transformer-Rectifier Power Supply
Battery Charger

3. Ampere-Hour Meter

4. Telemetry Monitor

Unidirectional Current Monitor
Bidirectional Current Monitor
Battery Voltage Monitor
Output Bus Positive/Negative 28 Volt Monitor
State of Charge Monitor
Power ON/OFF Signal Monitor
Battery Temperature Monitor

The mechanical design of the DC Power Supply was defined in outline form during Task I. Sufficient design was accomplished to establish system demands and to determine that no major problems were anticipated in the areas of heat transfer, mounting position

or packaging.

Task I concluded with preliminary electrical and mechanical design of the DC Power Supply.

Task II - Detail Design and Test Plan.

Finalization of electrical and mechanical design and definition of a test plan for each section of the Power Supply were the major objectives of the Task II phase of the program. The objectives of Task II were realized with no major problems encountered.

During Task II, NASA revised the original power system requirements which necessitated modifications of the EMPS252 DC Power Supply design. In addition to the NASA revision, Yardney Electric Company suggested an alternate battery charging method which resulted in further redesign of the DC Power Supply.

Power system design modifications were incorporated to provide a ground command signal circuit to override all logic functions; to accommodate manual control of the power relay; and include power transistors momentarily to by-pass the power relay contacts. The battery charger logic was designed to provide cut-off of the 8 ampere charge rate of 37 volts and cut-off of the 4 ampere charge at 38 volts respectively. The Ampere-Hour meter logic was designed to reset to 100% when the battery voltage, while under 4 ampere charge, reached 38 volts.

Design revisions accomplished during the "B" revision period of the study (March 1, 1968 to September 1, 1968) were made at NASA request or as a result of EMD engineering tests. The revisions include: Additional terminal lugs on the battery and power system cases; a provision for a system gas bottle heater; removal of the manual/automatic parallel provision for ground commands, and changing the power relay trip point to a higher value.

A complete description of system circuit functions is presented in Section III and the EMPS252 Drawing Package is presented in Appendix I. The block diagram of the DC Power Supply is presented on Figure 1.

208/120V
3Ø AC

*LEGEND

T-R: TRANSFORMER-RECTIFIER

A-H: AMPERE-HOUR METER

T: TEMPERATURE SENSOR

Q: STATE OF CHARGE




FIGURE 1. EMPS252 DC POWER SUPPLY,
SIMPLIFIED BLOCK DIAGRAM

Task III - Development (Model) DC Power Supply Fabrication.

EMPS252 DC Power Supply Unit No. 1 (Serial No. 26268) was fabricated to the configuration of Schematic Drawing No. 513911. The DC Power Supply was then tested in accordance with the Acceptance Test Procedure. Test data recorded during the Acceptance Test are presented in Appendix II, pages 14 through 16. During performance of the Acceptance Test a thermal heat map of Unit No. 1 was obtained. The Thermal Test Report is presented in Appendix III. After successful completion of the Acceptance Test, a 10,000-hour life test was initiated on Unit No. 1. The Life Test is scheduled for completion in September 1970. After completion of the 10,000 hour life test, a second 10,000 life test will be started. At the conclusion of the Life Test a Life Test Report will be submitted to NASA-Lewis Project Personnel.

Task IV - DC Power Supply Fabrication.

DC Power Supply Units 2, 3, and 4 were fabricated in accordance with the drawings presented in Appendix I. The Acceptance Test was performed on each of the three units at room ambient conditions only. These units were then subjected to a 100 hour cycling and burn-in test program. Acceptance Test Data recorded for Units 2, 3, and 4 are presented in Appendix II, pages 17 through 39.

II. DESIGN DISCUSSION

A. Power Supply Function

The primary function of the DC Power Supply is to supply power to the DC bus during all operational conditions. In addition, the DC Power Supply recharges its silver cadmium batteries while AC power is available from the Brayton alternator.

The DC Power Supply consists of two identical sections (not including logic and control functions) which constitute the +28 VDC and -28 VDC supplies. These two sections function in concert and simultaneously provide a level of fault isolation and redundancy.

The DC Power Supply system provides numerous telemetry outputs for overall system monitoring. These outputs also supply four separate control command operations which may be generated externally from the system. Successful system recycling is dependent upon the initiation of one of these commands.

B. Power Supply Design

The DC Power Supply consists of three individual subsections in three interconnected containers as shown on Figure-2. The positive and the negative batteries comprise two similar battery package subsections. The third subsection is the electronics package. All of the Power Supply elements except current shunts, thermistors, and batteries are contained in the electronics package. The physical characteristics of the DC Power Supply are presented on the following table.




FIGURE 2 BRAYTON CYCLE DC POWER SUPPLY BLOCK DIAGRAM

DC POWER SUPPLY PHYSICAL CHARACTERISTICS

POWER SUPPLY SUBSECTION	BASE DIMENSION (inches)	HEIGHT (inches)	WEIGHT (pounds)
Battery Package #1	10 x 10	10 1/4	140
Battery Package #2	10 x 10	10 1/4	140
Electronics Package	20 x 10	4	30
TOTAL WEIGHT:			310 pounds

The following paragraphs describe the elements of the DC Power Supply:

Logic Circuit: An assembly of voltage comparators and multivibrators (a majority of which are duplicated for the +28 volt and -28 volt power units) which control the Power Supply during normal operating modes, provide external command interfaces, and dictate the priority and relationship of the DC Power Supply automatic functions.

Transformer-Rectifier: Two multiple winding transformers and a diode assembly which convert the 208/120 VAC input from the system alternator to ± 28 VDC bus power and ± 42 VDC for battery charging.

Battery Charger: Two very similar series regulator current limited circuits--one for the +28 volt battery and one for the -28 volt battery. Each charger has two separately controlled sections. Each section supplies a 4 ampere charging current (total of four 4 amp sections).

Battery: A fifty cell silver-cadmium unit with a common center point is physically divided into two packages which comprise the +28 volt and -28 volt batteries.

Ampere-Hour Meters: Two separate sections which indicate the charge state of the +28 volt and -28 volt batteries, respectively, and also initiate battery charger action.

Telemetry: The composite of sense and conditioning circuits which sample DC Power Supply parameters and present them in standard form (0-5 VDC) for remote monitoring.

Power Relay: A bistable latching relay, which connects the DC Power Supply batteries to or removes them from the DC bus, is controlled either by internal logic or external command.

The elements described above are related to one another in the DC Power Supply system as shown in Figure 2. The output of the Brayton alternator (208/120 VAC, 1200 Hz, 3Ø) is fed to the transformer-rectifier (T-R) where it is converted to +28 VDC and ± 42 VDC. The ± 28 VDC power is connected directly to the DC Power Supply output terminals and serves as the Brayton System sources of DC power in the normal mode of operation. The positive and negative 42 VDC power is directed to the positive and negative battery chargers, respectively, and conditions the two twenty-five cell AgCd batteries. The T-R has one additional set of secondary windings which furnish a T-R undervoltage signal to the logic circuit.

The battery chargers for the positive and negative batteries are similar and are hard wired to their associated batteries. The positive or negative 42 VDC is series regulated by the chargers to a level associated with a fixed current value and the existing battery charge state. Each of the two battery charger sections is separately controlled by the logic circuit. During the charge mode either battery is thus charged by an 8 ampere current with both sections operating; this charge rate is reduced to 4 amperes when the charging voltage reaches a pre-determined point and one of the charger sections is turned off by the logic.

A power relay controls the basic operating mode of the DC Power Supply. During normal operation the positive and negative 28 VDC output from the T-R supplies bus power. If the alternator output drops below a pre-selected level (or if the alternator is shut down) the relay automatically connects the Power Supply batteries to the bus as an additional source

of power. The same relay also removes the battery from the bus after the shutdown cycle, and prevents battery drain during these possibly extended periods. The power relay is controlled either by internal logic or external commands.

The logic telemetry, and Amp-Hour Meter circuits monitor and control the internal operations of the DC Power Supply and the primary power functions described above. The details of these circuits are explained fully later in this report.

C. System Operation.

The Brayton Cycle Power Conversion System has five major operating modes: Normal Operation, Battery Charging, Alternator or Battery Operation, Manual Control, and System Shutoff. With the exclusion of the Manual Control mode (which is for emergency operation) the other (four) modes are required to complete one full system cycle. Each of these modes is discussed in detail below. Table I shows the various logic functions.

1. Normal Operation

The normal operation function of the DC Power Supply is to receive 120/208 volt, 3 phase, 1200 Hz power from the Brayton alternator and convert this to +28 and -28 volts DC for use in the Brayton PCS. The transformer-rectifier combination supplies the +28 and -28 volts output at currents up to and including 25 amps for both the positive and negative voltages. During normal operation the system battery is in a state of full charge and neither of the system's battery chargers are in operation. Only the bus monitor undervoltage circuit must remain functionally active.

UNIT	POSITION		OPERATING CONDITION OR COMMAND	REMARKS
POWER RELAY	CLOSED		1) $\leq 24V$ T-R Output 2) Manual "Close" Command	1) Manual command will override the logic by setting of control panel. 2) There are separate "open" and "close" commands. 3) T-R output sensed by separate secondary. 4) Any signal operates <u>both</u> Power Supply halves.
	OPEN		1) $\geq 25V$ T-R Output (with 5 Sec. Delay) 2) Manual "Open" Command	
BATTERY CHARGERS (Two chargers of two sections each)	O N	Lower half of one charger	Battery Voltage of 30.0V	1) Manual command overrides logic. / 2) There are separate "on" and "off" commands. 3) Battery overtemp overrides other automatic logic functions. 4) Manual commands operate both chargers--automatic commands operate relevant charger.
		Upper half of one charger.	Battery Voltage of 30.5V	
		One charger.	Amp-Hour Meter $\leq 90\%$	
		Both chargers.	Manual "On" Command	
	O F F	Lower half of one charger.	Battery Voltage of 37.0V	
		Upper half of one charger.	Battery Voltage of 38.0V	
		One charger.	Battery Temp $\geq 185^{\circ}F$	
		Both chargers.	Manual "Off" Command	

TABLE I. LOGIC FUNCTIONS OF THE EMPS252 DC POWER SUPPLY

The Amp-Hour meters are idle during normal operation, as no current is being supplied to, or being taken from, the system batteries. The telemetry circuits which provide, remotely, the parameters for a continuous system check, are functional in all the modes. During normal operation of the DC Power Supply, a minimum number of the system components are required to satisfactorily accomplish the DC Power Supply objectives. This condition is significant not only from the reliability standpoint, but also from the standpoint of heat dissipation. The Normal Operating mode will continue indefinitely as long as 1200 Hz power is supplied to the unit and if no external control is exercised. When the AC input voltage is reduced to a level below a pre-selected point, the secondary windings of the transformer will detect a bus undervoltage condition. When this undervoltage condition reaches the equivalent of 24 volts total, the appropriate voltage comparator circuit of the logic will energize power relay K1 and connect the battery in parallel with the transformer-rectifier output on the DC bus. When the bus voltage reaches the equivalent of 25 volts, the relay will open and cause the transformer-rectifier to supply the full load. There is a 5 second delay (a special feature of the reset) associated with the opening of the relay. This delay is provided to allow the Brayton alternator, at initial start condition, an opportunity to reach an operating point where it can supply the required voltage and current. Power relay K1 may be operated manually. For manual K1 operation a switch is provided on the control panel which overrides the automatic control of the relay by the logic power supply circuit and locks the relay in either the ON or OFF position.

Manual relay operation is fully discussed in Paragraph 4, which describes manual operation of the DC Power Supply.

2. Battery Charging Operation

The battery charging mode of the DC Power Supply may be defined as a supplement to normal operation. In this mode of operation the transformer-rectifiers are supplying +28 and -28 volts as previously stated. The transformers are also supplying +42 and -42 volts to the battery chargers through a separate set of rectifiers. There are two battery chargers consisting of four battery charging circuits. One battery charger is for the +28 volt battery and the other battery charger is for the -28 volt battery. These four circuits are almost identical except for slight variances in biasing due to their positive and negative placements within the system. Each of these battery charging circuits is a series voltage regulator which is current limited to 4 amps. The combination of two of these circuits in parallel will supply the associated battery with maximum charging current of 8 amps. From the system operation standpoint, the battery charging mode starts either when the Amp-Hour meter associated with the particular battery indicates a charge state below 90% or when the open terminal voltage of the battery reaches 30.5 volts. Under the first of these conditions the logic circuit associated with the specific battery charger will turn on both of the 4 amp sections. An 8 amp charging rate will continue until the terminal voltage of the battery reaches 37.0 volts. At this 37 volt point, one of the two chargers is turned off reducing the charging current to a 4 amp level. This 4 amp level continues until the charging terminal voltage of the battery reaches

a level of 38.0 volts at which time the logic turns off the second of the two charger circuits and the battery is assumed to be fully charged. The charging operation is accomplished concurrently with the normal operation of the transformer-rectifiers supplying bus power. Either one or both of the batteries may be charged during this mode, depending on their individual charge states. It is during this battery charging mode of operation, which obviously requires more power for the transformers and alternator, that the most demanding heat transfer condition is experienced. It is also during this operational mode that the logic circuits pertaining to battery over-temperature and the voltage comparators which sense battery terminal voltage commence to function. The battery temperature sensors will shut down the associated battery chargers if the battery reaches a temperature at which continued charging will injure the battery. The battery voltage comparators automatically control the operation of the battery chargers in shifting from an 8 amp charging current to a 4 amp charging current and then shutting off the battery charger. The battery charging mode may be initiated manually as well as through the automatic control circuits. The manual control (which is discussed in paragraph 4) will over-ride the automatic circuits. The manual control command circuits may also be used to initiate a charge cycle which will then be controlled automatically. This function was included within the system capability at the request of the battery manufacturer as the battery should be jolted to full charge every month or two rather than be supplied with a continuous trickle charge. If the battery is fully charged when the manual control is actuated momentarily, the battery chargers will be sequentially turned off within a very short period.

3. Alternator or Battery Operation Mode

When the output voltage of the transformer rectifier of the DC Power Supply drops below the 24 volt level, the system logic will energize power relay K1 and the system battery will be connected in parallel with the transformer-rectifier output. In the unlikely event of a partial failure of the system alternator, the battery and the transformer-rectifier will remain connected in parallel and each section will supply a portion of the system DC power requirements. However, it is likely that if the voltage from the transformer-rectifier drops below the 24 volt level, the alternator will have been removed as the source of input to the power system and the battery will remain connected across the output bus to furnish power to the bus loads such as in a normal phase of operation during a Brayton Cycle System shutdown. During this period, the Amp-Hour meters will record the discharge level of the batteries. The telemetry and logic circuits will be available for system control and monitoring. Since relay K1 is a bistable device, this condition will exist until either the alternator attains the required voltage level during start up or the system is being shut down.

4. Manual Control

Manual operation of the power relay is required when the Power Supply is to be completely shut down. It also provides an override function in the event that the automatic control circuits fail or if the battery must be placed on the bus to accommodate an unusually heavy load.

The configuration of the DC Power Supply operational cycle may be changed in the normal method through

functioning of the system's automatic controls and also by manipulation of the manual override features of the DC Power Supply. As stated previously, the power relay may be opened or closed manually. This manual function will completely override the automatic control circuits.

The battery chargers can also be operated in a manual mode. In this case, both of the battery chargers each containing the two 4 amp sections are operated simultaneously. The same is not true when the battery chargers are operated automatically by the logic circuits, in which case only the battery requiring a charge is serviced by its particular charger and comparator circuits. Manual battery charger operation completely overrides the automatic circuits of the power system and is provided only for emergency use. In the event that the logic circuits do not turn on a battery charger and it is known that the state of charge of the battery is low, the manual command can be used to initiate such a charge. Through careful monitoring of the telemetry signals, the battery charger can be turned off at the appropriate state of charge. If a battery charger should continue charging the battery beyond its full state of charge condition, or in the case where the battery temperature has exceeded its maximum safe charging level, the battery charger can be manually turned off.

The manual control function is also provided for another purpose. The battery manufacturer requested that a method of jolting the battery to full charge be provided within the system, this instead of the trickle charge which is often used in similar situations. The

time interval between charge jolts has been suggested to be between 4 to 8 weeks. It is not practical to include in the logic circuit a timing function to automatically turn on the battery chargers from within the system at these periods. (Engineered Magnetics suggested that the Battery Charger-On manual control be used to accomplish this function).

When the jolt charge is required, the battery charger manual on control is momentarily actuated and the chargers of both batteries will start their normal charging operation. Once started, this normal charging operation will be turned off by the normal (automatic) sequence of operation when the charging terminal voltage of the batteries reaches levels which indicate a state of full charge. This function has the advantage of being able to manually initiate battery charging while not having the fault of possible over-charging the battery due to inadequate monitoring.

5. Shutdown Mode

During the Brayton Cycle System shutdown, the battery is supplying power to the inverter coolant pumps and other bus loads. This is a normal mode of operation which has previously been discussed in the battery operation section.

When the system heat is dissipated or distributed, the shutdown cycle is completed, and it is desirable to have the battery placed on a stand-by condition in the event that it will be used in the motor mode of starting the Brayton alternator. The battery must therefore be disconnected from the bus but must be prepared to supply sufficient power to the logic circuits to enable the system to be turned on again. A manual command is first required to open power relay

K1. Now the battery is removed from the bus and is also removed from a position where it will supply power to the logic circuits, telemetry circuits, and the ampere-hour meters.

The power activating circuits for power relay K1 are connected directly across the battery and provide the capability of turning on the system again. The slight power loss due to the sense portion of the circuit will be less than internal losses in the battery during the inactive period and will not significantly effect the battery even during a shutdown period of several years.

D. Mechanical Design

The mechanical design of the EMPS252 DC Power Supply was determined in outline form only for Task I of the program. The outline characteristics and weight have not changed. In Appendix I are the outline drawing and the layout drawing the unit. The battery drawings were supplied to NASA under separate cover.

The DC Power Supply is contained in three sections. Two sections each contain one of the two battery packages. The third section contains the electronic components. Each of the sections are mounted on heat sinks provided by NASA.

1. Packaging Concept

The electronic circuit packaging concepts for the DC Power Supply shown in Appendix I are based on standard techniques which have been used successfully on many space power systems. Exceptions to standard approaches exist in areas relating to the high reliability and long life requirements of the Brayton Cycle Power Conversion System.

The package configuration is one of low profile and large baseplate area. This design incorporates maximum heat transfer area to the coldplate, short thermal paths to the baseplate, and rigid mounting surfaces for the internal electronic components. The main structural member of the unit is an aluminum baseplate. Cover mounting flanges, connector support brackets, internal heat sink brackets, and component mounting brackets are dip brazed to the baseplate. This method of construction optimizes weight, thermal, and structural considerations.

Weight savings are realized through use of brackets fabricated from thin aluminum sheets brazed to the baseplate. Arriving at the same configuration using machined parts would result in thicker sections and unnecessary excess metal in certain areas. In addition, machined parts are inherently more costly and time consuming to fabricate and more restrictive of design flexibility.

Thermal performance is enhanced by dip brazed construction thus eliminating heat barriers that exist if semiconductor brackets, for instance, are bolted to the baseplate instead of being joined by a continuous faying surface fusion of metals.

Structurally, brazed joints offer good resistance to fatigue failures during vibratory loading. Relative motion, as would occur between bolted joints, is eliminated by brazing the joint. Brazing provides a ductile interfacial material that is not brittle or susceptible to fatigue cracks that can occur with welding.

The cover of the container is of formed aluminum sheet. It is attached to the base assembly by screws to a mounting flange. This type of attachment, with

the cover overlapping the flange, provides EMI shielding and protection from foreign contaminants.

The basic approach being established, the detailed design considerations were governed by reliability and long life requirements. Due to size of the unit and nature of components it is not practical to hermetically seal the case. Instead, the unit is protected from earth associated contaminants such as moisture, salt spray, and sand and dust. Materials that out-gas or deteriorate under extended periods in hard vacuum are not used. Heavy current carriers are terminated at bolt and lug connections rather than by ordinary pin and socket connectors.

2. Thermal Considerations

The only mode of heat transfer from the unit is conduction to the coldplate. Temperature gradients between the coldplate and unit baseplate are minimized by closely spaced mounting attachments. The baseplate surface in the vicinity of the mounting attachments is machined smooth and flat in accordance with NASA requirements. Only four square inches of base area around each attachment are considered as heat transfer area. A joint conductance of $100 \text{ Btu/Hr Ft}^2 \text{ } ^\circ\text{F}$ is assumed for this area. The internal components are arranged to distribute the heat evenly to minimize thermal path lengths to the heat transfer area. The heavy power transformers are mounted directly to the baseplate. The lighter windings, power diodes and charger diodes are mounted on a vertical bracket with direct thermal paths to the baseplate. Battery charger and power supply components are also paths to the baseplate. Series regulator transistors are the most critical components from a thermal viewpoint. Special considerations such as indium foil interfacing materials and installation at a favorable

coldplate location are required in order to maintain their temperatures at a reliable limit. Low level circuits are mounted on circuit boards grouped in a subassembly. These components do not require special treatment or close scrutiny for thermal considerations.

The power dissipation characteristics of the DC Power Supply subsections are presented in the following table. Based on the dissipations shown on the table, a heat transfer area of 120 square inches and a joint conductance of 100 Btu/Hr Ft² °F, a baseplate thermal profile was calculated. The maximum baseplate temperature occurs immediately under the power transformer. This temperature, which is approximately 110°C, allows a gradient of 70°C to the transformer rated temperature. The series regulator transistor junction temperature is approximately 140°C. This can be decreased to be less than 110°C with indium foil mounting on the transistor insulator and a location on the coldplate that provides a coolant temperature of 125°F instead of 150°F. For proper derating of the transistor, its temperature should not exceed 110°C in this application. The balance of the baseplate is within 5°C of the coldplate surface.

UNIT	Power Dissipation (Watts)		
	Full Load Full Charge	Full Load Half Charge	Full Load No Charge
Transformers	120	95	70
Power Rectifiers	25	25	25
Charging Rectifiers	8	4	0
Battery Chargers	160	55	0
Logic and Telemetry	8	8	8
Amp-Hour Meters	12	12	3
TOTAL	333	199	106

III. POWER SUPPLY CIRCUIT DESCRIPTION

A. Control Logic

The control logic (shown in two blocks of Figure 2) selects the rate of charge to the batteries, determines whether the batteries are to be connected to the DC bus, and determines when the ampere-hour meters are to be reset to show that the individual batteries are fully charged. In addition to the logic diagram on Figure 3, a table of logic functions is provided on Table I. The table presents information on the state of the system for various operating conditions without tracing through the logic diagram.

Automatic control inputs to the logic are battery voltage, battery state of charge from the ampere-hour meter, battery temperature and bus voltage. In addition to the automatic control inputs, two manual commands are provided that can override all other inputs. One manual command turns the chargers full on or off, the other manual command closes or opens the relay that connects the batteries to the DC bus. The logic circuits (except for the circuit that drives the relay) are powered from the +28 volt DC bus and not directly from the battery. The relay drive circuits are connected directly to the battery and require power only during the instant that the relay changes state.

Figure 3 is the block diagram of the control logic. All the controlling inputs are shown on the left side of the figure and all the controlled outputs on the right side of the figure. Amplifier designations and input-output tie points are included so that functional areas of schematic diagram 513911, can be identified.

Logic operation is normally automatic, with the comparators providing an "on" or "off" output signal depending upon the magnitude and the previous state of the parameter measured.




FIGURE 3 EMPS252 DC POWER SUPPLY CONTROL LOGIC BLOCK DIAGRAM

Each comparator has a turn on level and lower turn off level. The output state of the comparator between the "on" level and the "off" level is that of the last level crossed. All logic outputs are "on" or "off" states (the chargers operating at 0, 4, or 4 + 4 amperes) so the "on" or "off" states of the comparators coupled through the appropriate gates and time delays shown in Figure 3 are used to control the logic outputs. Besides using the comparator output states for control, the output on-to-off transition at the 90% full charge level of the ampere-hour meter comparators is used to start the battery charge. This step is necessary because the battery voltage at 90% full charge is at almost the same level as the battery voltage at full charge, while the difference between the upper and lower levels of the battery voltage comparators is a much larger voltage. So if charging is stopped at a battery voltage of 38 volts it will normally not start charging until the battery voltage drops to approximately 30 volts unless the charge is started by using the on-to-off transition of the ampere-hour meter comparator to momentarily reset the battery voltage comparators back to start at 0 volts. This condition forces the battery voltage comparator output state between the higher and lower sensing levels to be that of the lower sensing level allowing charge to continue until maximum battery voltage is reached. The only other logic function is the 5 second time delay that delays removal of the battery from the bus.

To understand the relationship of the logic functions shown in the block diagram, Figure 3, and schematic drawing 512911, first it is noted that the actual mechanization of some logic blocks can be combined into one logic circuit element and the logic functions may be accomplished with more logic blocks than those shown. However, all of the comparators and connection points shown in the block diagram are identical to

those on the schematic. In addition, many of the circuits can be associated with single logic blocks.

Since most of the logic functions are performed with transistors that are either "on or "off" or with simple diode OR gates, the detailed circuit description of the logic will be confined to the comparators, one shots, flip flops, time delay, and relay drivers. Power for the logic circuits is supplied from a series regulator operating from the +28 volt DC bus and from a Zener diode shunt regulator operating from the -28 volt DC bus.

Comparators: The nine integrated circuit comparators are Fairchild type $\mu A710$, which have inverting and non-inverting input terminals. A voltage proportional to the controlling parameter is applied to either the inverting or non-inverting input and a reference voltage is connected to the opposite input. Adjustable hysteresis is obtained by connecting a selected-in-test resistor from the comparator output to the non-inverting comparator input. When the comparator turns on, the voltage level at the non-inverting input is raised.

This addition of some of the output current to the input signal results in lowering the signal voltage to the level at which the comparator will turn off. Once the comparator turns off, however, the turn-on level is restored to the previous, higher voltage state.

One Shots: All of the one shots used in the logic circuits, capacitor couple the off-to-on transition of a comparator (or transistor switch) through a series connected resistor and capacitor to the base of another transistor. The time constant of the series connected resistor-capacitor is approximately the duration of the resulting pulse.

Time Delay: Whenever the battery is to be disconnected from the 28 volt DC Bus, a 5 second time delay is initiated and the battery is disconnected. The time delay period is the time required to charge C2 through R14, (see schematic 513911) until the base-emitter junction of Q7 starts to conduct.

The time delay is started by turning off Q8. The firing of Q7 momentarily turns on Q6 which resets bistable flip flop FF1 to the reset state where output pin 9 is in the on state and output pin 6 is in the off state. FF1's transition is then coupled through C1 and R7 to momentarily turn on the appropriate relay drivers.

FF1 is placed in the set state (output pin 9 is off and output pin 6 is on) by giving the "connect battery" relay manual command at initial system turn on or by the bus voltage dropping below 24 volts. Setting of FF1 is accomplished by the turning on of Q5 when comparator A1 is turned on by a low bus voltage or by a momentary ground command to close the relay.

FF1 also performs additional functions. When FF1 is in the reset state (output pin 9 is on and comparator A1 is off) the time delay is prevented from oscillating by the signal from FF1, pin 9 through CR9 because Q8 is then held on thus shorting out time delay capacitor C2.

The output of pin 6 of FF1 through its relay drivers connects the battery to the bus in the same way that the output of pin 9 disconnects the battery from the bus.

Relay Drivers: The relay drivers provide the momentary 28 volt signal used to change the state of the relay. The two relay drivers are the combination of Q3 and Q4 and the combination of Q9 and Q10. The relay drivers are simply Darlington connected transistors (DC current gain ≈ 1000) in series with the battery and relay coils. Momentary base current for turn-on is provided through the series coupling capacitors from the change in state of FF1.

B. Transformer-Rectifier and Battery Charger


Transformer-Rectifier

The transformer-rectifier circuit of the DC Power Supply, shown on Drawing 513911, is a 3 phase input, 12 phase output configuration.


The following characteristics were the major considerations for the selection:

- High efficiency
- Low ripple
- Low internal impedance
- Low input power waveform distortion
- High input power factor
- Redundancy.


Two transformers are connected to produce a 12 phase output from a 3 phase input. One transformer has a 3 phase Wye primary and a 6 phase star secondary winding.



The other transformer has a 3 phase Delta primary and a 6 phase star secondary winding.




When combined, the corresponding windings of the two transformers are 30° out of phase, and form a system circuit having a 12 phase secondary:




By connecting each secondary winding to rectifier anodes and connecting the rectifier cathodes to the positive terminals, a 12 phase half wave transformer-rectifier circuit with a negative common is obtained. (See diagram below.) The DC output will have a theoretical 12 phase ripple of 3.41% peak-to-peak amplitude. The major disadvantage of this circuit is that each rectifier carries the full load for 1/12 of the cycle, or 30° . Only one rectifier, the one with the highest voltage, conducts at any given time. As soon as the voltage of one rectifier becomes highest, all other rectifiers are back biased and stop conducting until the next rectifier in sequence conducts for 1/12 of a cycle. This individual load carrying characteristic subjects each rectifier and transformer winding to high peak currents which are also reflected into the power source.

The following diagram shows 2 transformers, one with a Wye and one with a Delta primary, and both transformers with two 3 phase Wye half wave rectifier secondaries connected 60° out of phase.

12 PHASE OUTPUT TRANSFORMER CIRCUIT



Each of the four 3 phase Wye secondary half wave rectifiers will have a wave shape of the following configuration:




In a circuit with three interphase transformers, (T3, T4 and T5), the conduction time of each rectifier increases from 30° to 120° which causes the conduction time of the four half wave rectifiers to overlap and each will conduct $1/4$ of the load simultaneously, drawing current from four primary and four secondary windings, and reducing internal impedance by 4.

In the above waveform, rectifier a conducts 120° from 0 to 1. Rectifier b assumes the load and rectifier a is back biased. At point 2 rectifier c assumes the load, and b is back biased.

With independent loads, the SEC 2 wave shape is the same as SEC 1 except it is shifted 60° (broken line). Without an interphase transformer and with a single load applied at points +1 and +2 (reference transformer diagram), or with points +1 and +2 connected together, the interference between SEC 1 and SEC 2 will limit conduction time to 60° . The

interference zone is indicated by the shaded area of the waveform illustration.

By connecting point +1 to point +2 through interphase transformer T3, which is a center tapped autotransformer, a peak-to-peak triangular shaped voltage of $e = 1/2 E$, at three times the fundamental frequency is developed.



When the potential of the ϕ_a diode is higher than the potential of the ϕ_c diode, I_a flows from +1 to + and the voltage developed across +1 and +2 is such that +1 is negative (-) and +2 is positive (+). This condition raises the level at the ϕ_c diode and lowers the level at the ϕ_a diode. The amplitude of the ϕ_c voltage is raised and the potential of the two rectifiers are equal, causing them to conduct simultaneously every 120° with half of the load current carried by each rectifier.

In the transformer circuit, the 12 phase output is obtained by using two 6 phase circuits with interphase connections (T3 and T4). The two circuits are connected together by a third interphase transformer (T5). The voltage across transformer T5 is $e_1 = .14E$, with a frequency that is six times the fundamental with the two sets of six phases overlapping.

The diode cathodes, connected to the secondary winding, also attain the negative to ground output. Each negative diode conducts 180° out of phase with the positive diode and a sine wave is produced.

In the final circuit design shown in Appendix I, taps 4 and 7 of transformers T301 and T302 are connected to interphase transformer T306. Transformer T306 with the associated rectifier circuit provides the +40 VDC to the battery charger. Taps 4 and 7 of T301 and T302 are connected to interphase transformer T307 to obtain the -40 VDC for the battery charger.

Taps 3 and 8 of T301 and T302 are connected to T304 to obtain +28 VDC output. Taps 3 and 8 of T301 and T302 connected to T305 produce a -28VDC. The positive and negative 28 VDC is the power supplied to the system bus. Input power waveform distortion is maintained at a very low level by the continuous conduction of the primary windings.

Through the use of two transformers (i.e., T301 and T302), redundancy is obtained. In the event of a failure of one transformer, fuses will remove it from the circuit and the other transformer remains on the line. The remaining transformer will supply full output power, although the output ripple will be increased and the efficiency will be lower.

Battery Charger

The positive and negative 40 VDC battery chargers each contain two charging regulators. At battery full charge conditions, all four regulators are maintained at the off condition by a 1 volt signal applied to the individual turn on-turn off regulator control transistor circuits. For the positive 8 ampere charger output, two positive charging regulators are connected to charge the battery by the application of a zero volt signal to their control transistors. By applying the 1 volt turn off signal to one regulator control transistor and the zero volt signal to the other regulator control transistor, the 4 ampere charge mode is obtained.

When the 1 volt signal is applied, simultaneously, to the two regulator control transistors, the no-charge (charger off) mode is obtained. The negative charger regulator circuits are on or off as controlled by signals to the two negative regulator control transistors.

The positive charge voltage is obtained from tap 5 of T306. The negative charge voltage is obtained from tap 5 of T307.

Positive Charger Section 1: When the positive battery package is being charged at the 4 ampere rate, one positive regulator is on and one positive regulator is off. The charging current is high and the voltage to control transistor Q309 is zero, holding Q309 off. The parallel connected sensing circuit resistors R301 and R304 carry the full 4 amp charge current. Resistor R305 and Zener diode CR360 are the current limiting circuit. The voltage divider R302 and R305 provides the reference voltage comparison between the base voltage of Q309 and the positive 40 VDC. When the voltage across current measuring resistors R301 and R304 reaches the level determined by Q300, R303, R302 and CR360, the circuit operates as a current regulator.

When the voltage at Q309 switches to 1 volt, Q309 is saturated switching off Q304, Q303, and Q302, thus switching to the charger off condition.

Positive Charger Section 2: The second 4 ampere regulator functions through its respective circuits in the same sequence as the first 4 ampere section. The control transistor is Q310. CR363 and R306 are the current limiting circuit, and the voltage across CR362 is divided by R306 and R311. The second current regulator circuit is hence Q323, R312, R311, CR362, Q310, Q308, Q307, Q306.

Negative Charger Section 1: The zero volt signal applied to control transistor Q316 holds Q316 and Q312 off and the 4 ampere charge current is applied to the negative battery package. The current limiting circuit consists of diode CR366, Zener diode CR364 and resistor R320. The sum of the BVE of Q311, Q313, and Q314, plus the voltage of R323 is held constant by the current limiting circuit. When the voltage across R323 and R329 reaches the level determined by Q314, Q315, Q313, Q311, CR364, and CR366, the circuit operates as a constant current regulator.

The 1 volt charger off signal saturates Q316 turning on Q312, shorting out the CR366 and CR364, and the voltage of the current limiting circuit becomes zero.

Negative Charger Section 2: This 4 ampere charging section functions through its respective components in the same manner as described for the first negative 4 ampere section.

C. Ampere-Hour Meter

The basic function of the two ampere-hour meters is to integrate current flowing in the battery. This measure of integrated current or charge is then stored for read-out as a voltage that is directly proportional to the charge in the battery. The block diagram on Figure 4 illustrates the principal functional elements of the ampere-hour meter. The ampere-hour meter uses the shunt method of current detection and a readout that is a bi-directional stepping motor coupled to a potentiometer. Power is supplied to the ampere-hour meters either from the 28 volt DC bus or from the battery when the system gas bottle heaters are operating. For simplicity, the power supply connections are omitted from the block diagram. The millivolt signal from the shunt is applied at the input of the ampere-hour meter circuit. In essence, it looks directly at an R/C charge circuit.

The capacitor of the R/C charge circuit is periodically pulled down to a negative voltage by the feedback path each time the input capacitor voltage reaches zero volts. The time it takes the voltage across this capacitor to return to zero is a function of the R/C time constant and the voltage appearing across the shunt which is proportional to the charge or discharge current. From this information it can be seen that the frequency of this sawtooth waveshape appearing across the R/C charge circuit will vary. If a memory of the total number of pulses during any charge or discharge cycle is maintained, the total current to or from the battery is integrated with respect to time. As the voltage across this capacitor rises to a predetermined point, it is necessary to detect the level in some manner.

With this integrator, this point is selected to be zero volts rather than some other level for several reasons. First, and perhaps the most important reason, zero detectors




FIGURE 4. AMPERE-HOUR METER BLOCK DIAGRAM

are inherently more accurate devices than are other types of level detectors, such as Schmitt trigger, unijunction, or SCR devices. In addition, resetting poses no difficulty and zero detectors can operate from an extremely low level signal.

The trigger portion of the circuit is simply an actuator of the feedback signal which "discharges" the input capacitor to a negative voltage. The number of pulses is sensed at the feedback point. Each pulse registers on a flip-flop which changes state on each successive pulse. The output of this flip-flop is conditioned by three cascaded flip-flops, each dividing the number of pulses by 2, and a Darlington connected buffer circuit which drives the stepper motor. After every 8th pulse the stepper motor rotates another increment. It is this device that provides the memory and accomplishes the integrating. The readout is simply a state-of-charge indicating potentiometer driven directly by the stepper motor.

In order to eliminate cumulative errors, the ampere-hour meter memory is reset when the battery is fully charged as indicated by the battery voltage comparator. The ampere-hour meter reset function is performed by a unijunction oscillator coupled through an "OR" gate to the stepper motor.

A basic schematic for the ampere-hour meter is presented on Figure 5. With the exception of the power supply, each of the functional elements of this circuit corresponds to the block diagram. The purpose of




FIGURE 5 AMPERE-HOUR METER SIMPLIFIED SCHEMATIC

having the two identical channels shown on the schematic, is to allow integration of both charge and discharge battery current. Because of its secondary importance, the power supply will be discussed last; although it would appear from the schematic to be first in line

The input signal is derived from the current shunt in the battery bus line. This signal is in the order of a very few millivolts and is directly proportional to the charge or discharge current of the battery. The polarity of the signal determines which channel is activated. While one channel is integrating, the other one does not operate since it is designed to operate with a signal of the opposite polarity.

The R/C charge circuit is composed of resistors R204 and R205, and capacitor C205. The resistor arrangement in the R/C charge circuit is incorporated to allow for the calibration of each instrument. This adjustment is necessary to get maximum accuracy. As shunt voltage is applied to the R/C charge circuit, the voltage across capacitor C205 will begin to rise at a rate determined by the R/C time constant. The voltage across the capacitor is applied directly to the input terminals of the integrated circuit amplifier, A201. This amplifier is connected to operate as a zero detector. The voltage divider arrangements, resistors R206 through R209, provide the necessary offset adjustment shown in the block diagram. It is in this network that final resistance values are determined during production testing.

After Q205 fires, the change of voltage in C209 will be

$$\Delta V_{C209} = V_{FWD} \text{ SCR Q205} - V_{Zener} \quad (1)$$

and, neglecting I^2R losses, the corresponding voltage change on C205 will be

$$\Delta V_{C205} = (V_{FWD} \text{ SCR Q205} - V_{Zener} + V_{FWD} \text{ CR211}) \frac{C209}{C205 + C209} \quad (2)$$

If $C209 \ll C205$

Then,

$$\Delta V_{C205} = (V_{FWD} \text{ SCR Q205} - V_{Zener} + V_{FWD} \text{ CR211}) \frac{C209}{C205} \quad (3)$$

In general,

$$Q = CV = \int_0^T i \, dt \quad (4)$$

So during reset,

$$Q_{C205} = C205 (V_{FWD} \text{ SCR Q205} - V_{Zener} + V_{FWD} \text{ CR211}) \frac{C209}{C205} \quad (5)$$

and after reset

$$\int_0^T i_{1n} \, dt = C209 (V_{FWD} \text{ SCR Q205} - V_{Zener} + V_{FWD} \text{ CR211}) \quad (6)$$

Assuming I_{1n} is approximately constant,

$$I_{1n} = \frac{E_{1n}}{R_{1n}} \quad (7)$$

then,

$$\frac{E_{1n}}{R_{1n}} T = C209 (V_{FWD} \text{ SCR Q205} - V_{Zener} + V_{FWD} \text{ CR211}) \quad (8)$$

from which,

$$T = \frac{R_{1n}}{E_{1n}} C209 (V_{FWD} \text{ SCR Q205} - V_{Zener} + V_{FWD} \text{ CR211}) \quad (9)$$

As shown by equation 9, the frequency of the ripple voltage on the R/C charge circuit is proportional to the input voltage and several other parameters which remain constant and is independent of the value of C205. These constants are the

only sources of error in the system. It is, therefore, necessary to direct particular attention to the stability of these components. If extreme accuracy were required it would be necessary to temperature compensate for V_{FWD} SCR Q205 and V_{FWD} CR211 voltage changes.

As the feedback storage capacitor C209 is cycling at the frequency of the input ripple voltage, by AC coupling this device through C210 to the integrated circuit flip-flops each successive pulse registers a distinct change of state. Each output channel of the flip-flops is coupled to the Darlington buffer circuits.

The output of the buffer circuits appears in the form of a pulse. These pulses are used to sequence the stepper motor. Each successive pulse appears on alternate channels. Regardless of which channel produces the pulse, the stepper motor is sequenced another increment. With this action, accurate integration is accomplished.

The DC Power Supply furnishes all of the bias voltages required for the integrator. The power supply itself is simple. It comprises an input series regulator and a magnetically coupled DC converter to perform the DC to AC conversion. The AC output of the converter is full wave rectified to provide the appropriate DC output voltages.

D. Telemetry

The DC Power System telemetry provides standard 0 to 5 volt analog signals to measure temperatures, voltages, currents and battery states of charge. The telemetry is designed so that a short circuit or open circuit of any of the telemetry outputs will not disable any of the main system functions. The output load for the telemetry should be greater than 100,000 ohms, (1 megohm is standard) for good accuracy.

Battery State of Charge Telemetry

Battery state of charge is taken directly from the ampere-hour meter potentiometer readout through a series failsafe isolation resistor. State of charge is directly proportional to telemetry voltage.

Voltage Telemetry

Voltage sensors are simply voltage dividers composed of resistors with better than ± 100 parts per million per degree centigrade temperature coefficients.

Temperature Telemetry

Battery temperature is sensed by internal thermistors that are part of a simple resistor voltage divider network supplied from a reference Zener diode. The temperature versus voltage characteristic is non-linear so temperature versus output voltage calibration curves are necessary for each channel.

Current Telemetry

Current transducers are used to measure the current in the + 28 volt bus and in the -28 volt bus and the currents into or out of the batteries.

Each of the four transducers is supplied from a separate DC to AC converter that is fused so that failure of any one converter will not damage the system and will not destroy all of the current monitors. The 28 volt bus current range is from 0 to 50 amperes and the battery monitor current range is from -10 amperes to + 40 amperes. Charge current is considered negative.

E. Power Relay

The power relay functions to connect or disconnect the batteries from the positive and negative 28 VDC buses. This bistable latching type relay is energized by a pulse supplied by the logic circuits. In addition to the bus contacts, the relay has

two sets of contacts used for signaling the position of the relay. One set of contacts closes to provide a relay position indication signal when the bus relay contacts are closed. The other set of contacts closes to provide a relay position indication signal when the bus relay contacts are open.

F. Battery System

The battery system for the EMPS252 DC Power Supply is composed of two identical canisters, each of which contains twenty-five sealed silver-cadmium cells, two thermistors and current measuring shunt. These units function as the + 28V and - 28V batteries within the system. The batteries are rechargeable and provide output bus backup capability as well as required energy for start-up and shutdown of the Brayton System.

The cells within the batteries are Yardney type YS-85(S) cells and have a nominal power rating of 85 ampere-hours. Each cell was epoxy sealed after test and no preventive maintenance is required.

The thermistors used in each canister are Gulton Model 35TD25 devices. The units are attached to the center cell within the 5 x 5 battery matrix. One thermistor is provided as a telemetry output, the other thermistor indicates battery temperature to the DC Power Supply internal logic.

Each battery canister also contains an Empro type A-50-100 current shunt in the negative leg of the circuit. The voltage signal from this shunt is directed to the appropriate ampere-hour meter within the DC Power Supply logic which indicates at all times the state-of-charge of the associated battery.

IV. RELIABILITY

Reliability Estimate.

The following reliability estimate for the DC Power Supply is based on the total electrical component parts count and utilizes component part failure rates and other estimating techniques as outlined in the Engineered Magnetics Reliability Handbook. As substantial circuit changes have occurred since the previous Reliability Estimate was submitted to NASA, this Reliability Estimate updates that report as a final submittal.

Certain basic assumptions were used in the preparation of this Reliability estimate and are defined as follows:

1. No workmanship errors exist in the assembling of the components into a complete unit at EMD to contribute to a system failure (i.e. special controls and procedures were devised to eliminate this failure mode).
2. Failure of any part used in the calculation will constitute a system failure.
3. Ambient temperature is 40°C.
4. All component parts are used with proper deratings at the maximum temperature and load condition(s).

The MTBF is calculated by using the reciprocal of the summation of the individual component part failure rates, i.e.,

$$MTBF = \frac{1}{\sum \lambda_i}$$

where: λ_i = failure rate of individual component part.

The MTBF for the DC Power Supply is 62,464 hours. The reliability

of the individual sections was calculated and the failure rate (failures/ 10^8 hours) for the section was determined. The summation of these sections was accomplished as indicated in the following:

$$\begin{aligned}\sum \lambda_s = & \lambda_{ps} + \lambda_{+42} + \lambda_{-42} + \lambda_L + \lambda_{AH} \\ & + \lambda_T + \lambda_B + \lambda_{PR}\end{aligned}$$

where: λ_s = failure rate of the section

λ_{ps} = failure rate of Power Supply

λ_{+42} = failure rate of +42V Regulator

λ_{-42} = failure rate of -42V Regulator

λ_L = failure rate of Logic

λ_{AH} = failure rate of Ampere-Hour meter

λ_T = failure rate of Telemetry

λ_B = failure rate of Battery

λ_{PR} = failure rate of Power Relay

$$\begin{aligned}
 \Sigma \lambda_s &= 150 + 119.82 + 113.81 + 387.64 + 492.60 \\
 &\quad + 197.04 + 100 + 40 \\
 &= 1600.91 \text{ failures}/10^8 \text{ hours}
 \end{aligned}$$

The MTBF is

$$\begin{aligned}
 \text{MTBF} &= \frac{10^8}{1600.91} \text{ hours} \\
 &= 62,464 \text{ hours}
 \end{aligned}$$

V. TEST PLAN

Development Test

Circuit operation tests were conducted on the engineering breadboards of the A-H Meter, logic, battery charger, and telemetry functions to determine proper circuit operation, circuit stability and to verify set points and biasing. Tests were conducted on the first unit transformer-rectifier to confirm functional characteristics and operation.

Battery Characteristics: These tests function to confirm the charge, discharge, and steady state characteristics of the battery assembly.

Operation: Tests were conducted on the assembled Power Supplies (including battery) to determine integration problems, unstable modes of operation or mismatches in circuit set points and biasing. The functioning of the manual commands and power relay was also checked at this time.

DC Power Supply Characteristics: The first assembled DC Power Supply unit was tested to determine functional characteristics. During these tests the steady state power quality and output transients due to input power variations (including operation of the power relay) were measured and sample measurements obtained are to confirm the assumed reliability stress levels.

Thermal Test

Thermal map measurements determine the internal and interface heat transfer characteristics of the system electronic package of the first deliverable system after completion of other functional tests. These tests function to confirm the thermal analysis and locate critical component temperature levels. See Appendix III for the Thermal Test Report.

Acceptance Test

Engineered Magnetics Test Procedure for EMPS252 Brayton Cycle

DC Power System (EMD Procedure No. 713331) presented in Appendix II, is the Acceptance Test Procedure for the DC Power Supply. The Acceptance Test, functional in nature, was performed to assure circuit operation.

Life Test

At the completion of the operational tests of Unit No. 1, a 50 cycle, 10,000 hour endurance test (Life Test) was initiated. When this test is completed, another 10,000 hour, 75 cycle life test will be performed using battery simulators instead of actual batteries. A special secured area was established for the purpose of preserving the test. This area is immediately adjacent to the installation location of the 1200-cycle, four-wire, three-phase, extended-life motor generator set, which was purchased under the contract specifically for the life test. The equipment within the secured test area are:

1. The DC Power Supply
2. Battery canisters 1A and 1B
3. Motor generator control panel
4. Power Supply load bank
5. Two Rustrak, dual-channel, Tymesshare recorders
which continuously record the following system parameters: positive and negative output voltages, positive and negative output current, positive and negative battery terminal voltages, positive and negative battery current (bi-directional)
6. Ventilation equipment for system loads and test equipment
7. Overload and battery protection circuits, and
8. Test failure alarm system.

Since its initiation, the Life Test has proceeded continuously, on a 24-hour-a-day basis (except for several equipment malfunctions and two commercial power interruptions). Monitoring by the Rustrak recorders is continuous. Operational time is recorded from the operating hoursmeter of the motor generator control panel which is directly related to the number of hours the

DC Power Supply has been under test.

Except when an operational cycle is run, monitoring of the test setup takes place on a daily basis. Protective circuits associated with the motor generator, the input fusing to the unit under test, and the external protective circuits which will remove a badly discharged battery from the test setup loads insure that a malfunction will not cause permanent equipment damage between monitoring periods. When a test cycle is to be performed, the unit is manually sequenced through battery loading during the beginning of a normal day shift. The unit is then set to perform the automatic battery charging operation and is monitored at approximately one hour intervals. A provision is made so that additional monitoring at the same periods takes place during the second shift. To date, the Life Test has continued satisfactorily.

VI. CONCLUSIONS

Design and development of the DC Power Supply (EMPS252) were satisfactorily completed by the Engineered Magnetics Division of Gulton Industries, Inc., and the four fabricated DC Power Supplies (with the exception of the batteries) met or exceeded the purchase specification for the unit with no deviations or waivers required. System testing of the DC Power Supply, as a part of the Brayton Cycle Power Conversion System program at the NASA Lewis Research Center and its Plumbrook facility, has demonstrated the compatibility of the DC Power Supply with other Brayton Engine components. The life testing presently being conducted at the Gulton, Hawthorne, California facility also demonstrates that the DC Power Supply meets its required performance goals.

High reliability components were used in the fabrication of the DC Power Supply units of this contract, to support the developmental philosophy of the entire Brayton Program. Provision was made, however, for upgrading the MTBF of the DC Power Supply by using in its design only components which can be replaced by Ultra-High Reliability parts such as JANTEX parts. Such units, which can be fabricated by the simple expedient of substituting the Ultra-High Reliability parts upon a part-for-part basis in the present design, will considerably enhance the MTBF of the DC Power Supply. Since the present units meet the projected life requirements for an unattended Brayton Power System, the improved unit can exceed the projected requirements.

A considerable amount of redundancy or component failure tolerance was designed into the DC Power Supply, particularly in its transformer-rectifier power conversion section. This section, which accomplishes the primary work of the DC Power Supply by converting the 208 volt, 3 phase, 1200 Hz, AC power into positive and negative 28 volt DC power can withstand the loss of one of its two power transformers and approximately half of its

rectification elements and still deliver full rated output power, although at a somewhat decreased efficiency and higher ripple level. The control and logic sections of the DC Power Supply also provide, wherever possible, several alternate channels of control or backup logic modes. The Power Supply, which was designed for unattended space use of long duration, is completely satisfactory in its present configuration for its intended final mission use.

The DC Power Supply Program was thoroughly planned and conducted with a minimum of design and development work. While this approach proved to be quite successful, it did not provide the usual number of opportunities between breadboards, prototypes, and qualification units to incorporate design changes as such improvements presented themselves. The DC Power Supply's present configuration with the exception of the battery meets or exceeds all the requirements of its purchase specification, but a review of the overall program indicates four areas for further consideration in regard to modifications of future DC Power Supply designs.

1. The Power Supply control circuits were changed several times during the program to match slight modifications in the overall system control philosophy. Due to the program schedule, these changes were usually additions or modifications to the existing circuits. A review of the final control circuits, as compared with the latest system requirements, may result in some design simplification.
2. The charge scheme used in the presently configured Power Supply, including the use of ampere-hour meters for indication and control, should be reviewed for compatibility with other types of batteries (such as silver-zinc). In addition, Gulton

has developed and tested a circuit which charges batteries by a pulse demand method. This circuit, developed after the design of the DC Power Supply was completed, provides a method for improving the battery charging and battery charge control portions of the presently configured Power Supply, and has the additional capability of battery conditioning. A trade-off study of these possibilities should be undertaken before fabrication of future DC Power Supplies of this type.

3. The thermal heat map measurements has indicated the possibility of several improvements of the heat paths within the Power Supply. Improved reliability and optimization of these heat paths to "obtain" a more even distribution of the heat generated within the Power Supply can be accomplished by performing several simple physical design modifications to the Power Supply.
4. The state-of-the-art in Silver Cadmium batteries was not compatible with the five (5) year life objective of the Brayton program. Additional work is necessary to acquire a battery which can meet this five (5) year life requirement in the anticipated Brayton environment.

APPENDIX I

DRAWING PACKAGE

1. List of Material LM 513260
2. Outline and Specification 413249
3. Schematic Diagram 513911
4. Final Assémbly Drawing 513260

SYM	DESCRIPTION	DATE	APPROVED
A	REVISED PER E.O. 24951 <i>X</i> <i>[Signature]</i>	12/9/68	<i>[Signature]</i>

DATE 10-3-68		Gulton Industries, Inc. HAWTHORNE, CALIFORNIA	
DR L. C. JENKINS			
CHK <i>Lopez-Adams</i> 10/22/68		LIST OF MATERIALS EMPS-252	
ENGR <i>[Signature]</i>			
MECH ENGR			
REL ENGR			
PROJ ENGR <i>[Signature]</i> 13-14-23-68			
APPD <i>M. Kruse</i> 10/23/68	CODE IDENT NO.	SIZE	LM513260 A
APPD <i>[Signature]</i> 13 J McCombe	06509	A	
SCALE —		SHEET 1 OF 32	

NOTES: (UNLESS OTHERWISE SPECIFIED).

- 1 PURCHASE COUPLING WITH SOCKET HD CUP POINT SET SCREW PIC DESIGN P/N BE-1-B.
- 2 GRIND SHAFT FLAT ON ONE SURFACE $5/16$ LG X $1/32$ DEEP BEFORE ASSY.

CODE IDENT NO	SIZE	LM513260	A
06509	A		
SCALE —	SHEET 2		

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
1	413249							OUTLINE & SPEC.	
	513911							SCHEMATIC	
5	WL 513260							WIRE LIST	
10	79400							WORKMANSHIP STANDARD	
	79492							HAND SOLDERING OF ELECT CONNECTIONS	
	EMP 74960							MFR TOROIDAL WINDINGS	
	EMP 77430							PROCESS SPEC. COATINGS &	
15								ADHESIVES	
	EMP 77431							PROCESS SPEC. MIX & CURE	
								EPOCAST 202	
	710410							INST'L OF SOLID RIVETS	
	EMP 74444							IDENT & MARKING SPEC	
20	EMP 11019							POTTING & HANDLING PROCEDURE	
								FOR FLEXIBLE EPOXY RESIN	
	EMP 74446							PROCESS SPEC MTG METHODS	
								OF SEMI-CONDUCTORS	
	EMP 74447							PROCESS SPEC MTG METHODS	
25								OF SEMI-CONDUCTORS	
	EMP 711304							MTG INSTRUCTIONS OF FLAT	
								PACK SEMI-CONDUCTORS	
	#997							SILICONE VARNISH - DOW CORNING	
30									
35									
		SIZE		CODE IDENT NO					
		A		06509				LM 513260	
		SCALE				REV		SHEET	
		—				A		3	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
1	413249							OUTLINE & SPEC.	
	513911							SCHEMATIC	
5	WL 513260							WIRE LIST	
10	79400							WORKMANSHIP STANDARD	
	79492							HAND SOLDERING OF ELECT CONNECTIONS	
	EMP. 74960							MFR TOROIDAL WINDINGS	
	EMP 77430							PROCESS SPEC. COATINGS &	
15								ADHESIVES	
	EMP 77431							PROCESS SPEC. MIX & CURE	
								EPOCAST 202	
	710410							INST'L OF SOLID RIVETS	
	EMP 74444							IDENT & MARKING SPEC	
20	EMP 11019							POTTING & HANDLING PROCEDURE	
								FOR FLEXIBLE EPOXY RESIN	
	EMP 74446							PROCESS SPEC MTG METHODS	
								OF SEMI-CONDUCTORS	
	EMP 74447							PROCESS SPEC MTG METHODS	
25								OF SEMI-CONDUCTORS	
	EMP 711304							MTG INSTRUCTIONS OF FLAT	
								PACK SEMI-CONDUCTORS	
	#997							SILICONE VARNISH - DOW CORNING	
30									
35									
		SIZE		CODE IDENT NO					
		A		06509				LM 513260	
		SCALE				REV A		SHEET 3	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
36									
	513260	/						FINAL ASSY	1
	413283 -1	/						SUB CHASSIS COMP ASSY	1
40									
	413964 -1	/						COMP ASSY TB-10	1
	313963 -1	/						TERM BRD TB-10	1
45	313963 -2	/						BRD. BLANK	1
	313963 -3	/						INSULATOR	1
	3025B	/						TERMINAL LERCO	143
50									
	1247-14	/						SPACER CAMBION	6
55	EM79451	/						TSTR Q15 SOLITRON	1
	EM78324	/						TSTR Q219-222, 219A-222A	8
60	EM79430-1	/						DIODE, ZENER CR253	1
	AFIN645	/						DIODE CR233-244, 247, 248, 223A-244A 247A, 248A	28
65								MIL-S-19500/240	
	G1712939	/						DIODE, ZENER CR15 MOTOROLA (IN3022B MIL-S-19500/115)	1
	G2-53 -80 Ω	/						RES R39 DALE	1
70									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A	
						SHEET		4	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
71									
	G1 -1.5K				/			RES R40 DALE	1
75	RN55C5110F				/			RES R273,275, 276,278,273A 275A,276A,278A MIL-R-10509/7	8
	RN55C1620F				/			RES R281,281A	2
80									
	RN55C1542F				/			RES R285,286, 295,296	4
	RN55C1960F				/			RES R283,283A	2
85									
	RN55C1003F				/			RES R284,287 294,297	4
	RN55C5361F				/			RES R288,293	2
90	RN55C1002F				/			RES R274,277,274A,277A	4
	RN55C2261F				/			RES R299	1
	RN55C----F				/			RES R289,292 S.I.T. ≈ 20K TO 50K	2
95									
	RN55C----F				/			RES R280,282 280A,282A S.I.T. ≈ 50 TO 150Ω	4
	RN55C----F				/			RES R279,279A S.I.T. ≈ 100Ω TO 1K MIL-R-10509/7	2
100									
	G1 1K				/			RES R290,290A	2
105									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A	
						SHEET		5	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
106	EM710454H-12							CAP 39 _{ufd} 60V, C213	1
	EMUCYKOIBT103M							CAP 101 _{ufd} 50V, C4 EM711411	1
110	M39003/01-2043							CAP 2.2 _{ufd} 20V, C20, 224, 225, 224A, 225A (CSR13E225KL) MIL-C-39003/1A	5
115	M39003/01-2116							CAP 1 _{ufd} 50V, C226-231 (CSR13G105KL) MIL-C-39003/1A	6
	SERIES 27500							FUSE 0.25A F201, 202, F201A, 202A LITTELFUSE	4
120	313286-1							XFMR T202, 203 202A, 203A	4
	52063-1D							CORE MAG INC	1
	6001							CENTER WASHER OHMITE	4
125	1855-2							GASKET	4
	MS24762-C7							SCREW	4
	MS21043-04							SELF LOCK NUT	4
130	MS15795-303							WASHER-FLAT	4
	10038-DAP							TRANSIPAD THE MILTON ROSS CO	9
135	IN2976B							DIODE, CR46, MIL-S-19500-124	1
	RH10-125Ω							RES., R141 DALE	1
	RH10-200Ω							RES., R300 DALE	1
140									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV A		SHEET 6			

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
141	413278 -1	/						COMP ASSY TB4	1
	413277 -1	/						P.C. BRD ASSY TB4	1
145	413277 -2	/						BRD BLANK	1
	5075B	/						TERM LERCO	38
150	1247-9	/						STANDOFF CAMBION	6
	M39003/01-2043	/						CAP C26,27 MIL-C-39003/1A (CSR13E225KL)	2
	UBH771031X	/						COMPARATOR A6-9 FLAT PACK FAIRCHILD	4
155	EM79451	/						TRANS Q9 SOLITRON	1
	EM73531	/						TRANS Q10 RAYTHEON	1
160	EM74706	/						TRANS Q25-29,32 RAYTHEON	6
	EM74709	/						TRANS Q13,24,30, RAYTHEON 31,33,34	6
165	EM711477	/						TRANS Q14 MOTOROLA	1
	AF1N645	/						DIODE CR33-41,43-45,12,13 MIL-S-19500/240	14
	EM79430-1	/						DIODE, ZENER CR42 TRW	1
170	G2-53-2K	/						RES R87 DALE	1
	RS-2B-400Ω	/						RES R32 DALE	1
175	RC07GF 391J	/						RES R142 MIL-R-11/8	1
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A	
						SHEET		7	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
176	RC20GF362 J			/				RES R88 MIL-R-11/8	1
	RC20GF152J			/				RES R33,34 MIL-R-11/8	2
	RN55C51RIF			/				RES R106 MIL-R-10509/7	1
180									
	RN55C8660F			/				RES R113	1
	RN55C1001F			/				RES R24,26	2
185	RN55C3321F			/				RES R30,135,137,91, 139,123,125,127,93, 115,116,117,140,120	14
	RN55C4021F			/				RES R97	1
190									
	RN55C1002F			/				RES R4,35,36 89,74,5,77 100,101,107,108 110,111,112,121, 122,124,126, 128,132,134	21
	RN55C2152F			/				RES R86,90,132, 136,138	5
200									
	RN55C6812F			/				RES R102,105	2
	RN55C1003F			/				RES R114	1
205	RN55C----F			/				RES R96 S.I.T. $\cong 100\Omega$ TO 1K	1
	RN55C----F			/				RES R104,103 S.I.T. $\cong 5K$ TO 20K	2
210	RN55C3322 F			/				RES R23,25 MIL-R-10509/7	2
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A	
						SHEET		8	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
211									
	RN55C----F				/			RES R92,98,109 S.I.T. \cong 10K TO 60K MIL-R-10509/7	3
215	RN55C----F				/			RES R118 S.I.T. \cong 20K TO 100K	1
	RN55C----F				/			RES R119 S.I.T. \cong 2.49K TO 274K MIL-R-10509/7	1
220									
	M39003/01-2116				/			CAP C12-17,19 MIL-G39003/01 (CSR13G105KL)	7
	M39003/01-2043				/			CAP C18 MIL-G39003/01 (CSR13E225KL)	1
225	M39003/01-2139				/			CAP C3 MIL-G39003/01 (CSR13G186KL)	1
	10034-NYL				/			TRANSIPAD THE MILTON ROSS CO	12
	10038-DAP				/			TRANSIPAD THE MILTON ROSS CO	3
	EMUCYK01BT103M				/			CAP C21,28 EM711411	2
230	413276-1				/			COMP ASSY TB-3	1
	413275-1				/			P.C. BRD ASSY TB-3	1
	413275-2				/			BRD BLANK	1
235									
	5075B				/			TERM LERCO	43
	1247-9				/			STANDOFF CAMBION	6
240									
	U31993151X				/			FLIP FLOP FF1 FAIRCHILD	1
245									
		SIZE		CODE IDENT NO				LM 513260	
		A		06509					
		SCALE		—		REV		A	SHEET 9

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
246									
	U3H771031X			/				COMPARATOR A1,2,3,4,5 FAIRCHILD	5
250	EM73531			/				TSTR Q4 RAYTHEON	1
	EM79451			/				TSTR Q3 SOLITRON	1
	EM79458			/				TSTR Q7 G.E.	1
	EM74706			/				TSTR Q5,6,8,16-22, RAYTHEON	10
255									
	AFIN645			/				DIODE CR2,6,8-11,14 16-22,24-26 28-32,3,5 MIL-S-19500/240	24
260	IN752A			/				DIODE, ZENER, CR7, MIL-S-19500/127	1
	IN753A			/				DIODE, ZENER CR23 MIL-S-19500/127	1
	EM79430-1			/				DIODE CR27 TRW	1
265									
	G-2-53 -80Ω			/				RES R62 DALE	1
	RC07GF431J			/				RES R11 MIL-R-11/8	1
270	RC20GF362J			/				RES R37 MIL-R-11/8	1
	RN55C51R1F			/				RES R59,18 MIL-R-10509/7	2
	RN55C2740F			/				RES R13,129	2
275									
	RN55C6470F			/				RES R67	1
	RN55C1001F			/				RES R5,7,17,19,22 MIL-R-10509/7	5
280									
		SIZE		CODE IDENT NO					
		A		06509				LM 513260	
		SCALE		REV A				SHEET 10	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
281	RN55C3321 F	/						RES R38,44,45,46,31 69,70,71,75,77,79,81 MIL-R-10509/7	12
285	RN55C1002F	/						RES R9,10,12,13, 15,16,80,82,84, 47,48,52,53, 54,60,61,64,65, 66,74,76,78,	22
290	RN55C2052F	/						RES R42	1
295	RN55C3322F	/						RES R83,85,6,20,21	5
	RN55C4641 F	/						RES R50	1
	RN55C6812F	/						RES R55,58	2
	RN55C1003F	/						RES R14,68,8	3
300	RN55C----F	/						RES R49 S.I.T. $\cong 100\Omega$ TO 1K	1
	RN55C----F	/						RES R56,57 S.I.T. $\cong 5K$ TO 20K	2
305	RN55C----F	/						RES R43,130,51,63 S.I.T. $\cong 10K$ TO 60K	4
310	RN55C----F	/						RES R72 S.I.T. $\cong 20K$ TO 100K	1
	RN55C----F	/						RES R73 S.I.T. $\cong 2.49K$ TO 2.74K	1
315								MIL-R-10509/7	
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A	
						SHEET		11	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
316									
	RN55C----F				/			RES R41 S, I, T ≅ 500Ω TO 2.5K MIL-R-10509/7	1
320	M39003/01-2116				/			CAP-C5-9,11,24,25 MIL-C-39003/1A (CSR13G105KL)	8
	M39003/01-2043				/			CAP C10 (CSR13E225K4)	1
	M39003/01-2139				/			CAP C1 (CSR13G186KL)	1
325									
	M39003/01-2055				/			CAP C2 MIL-C-39003/1A (CSR13E476KL)	1
	10034-NYL				/			TRANSIPAD THE MILTON ROSS CO	11
	10038-DAP				/			TRANSIPAD THE MILTON ROSS CO	2
330	EMUCYK01BT103M				/			CAP C22,23,31 EM711411	3
	413280 -1				/			COMP ASSEY TB5&6	2
	413279 -1				/			P.C. BRD ASSEY TB5&6	1
335	413279 -2				/			BRD BLANK	1
	5075B				/			TERM LERCO	26
	1247-13				/			STANDOFF CAMBION	6
340									
	U3A770931X				/			COMPARATOR A201,202 FAIRCHILD	2
	U31993151X				/			FLIP-FLOP FF201-FF208 FLAT PACK FAIRCHILD	8
345									
	G174706H				/			TSTR Q203,209,211 208,215,217, 225	7
350	GI 74709H				/			TSTR Q207 RAYTHEON	1
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A SHEET 12	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
351									
	GI73531H		/					TSTR Q212,210, 216,218 RAYTHEON	4
355	GI79458		/					TSTR Q204,206,213 G.E	3
	GI76096		/					TSTR Q205,214 G.E	2
	IN751A		/					DIODE,ZENER CR214	1
360								MIL-S-19500/127	
	GI79430		/					DIODE,ZENER,CR254,255,213, CR 221 TRW	4
	AFIN4645		/					DIODE CR211,212,222,251, 223,224,230,252,249, 215-220,250,256	17
365								MIL-S-19500/240	
	RN55C51R1F		/					RES R212,216,218 224,248,249	6
370								MIL-R-10509/7	
	RN55C2050F		/					RES R250	1
	RN55C5621F		/					RES 205,241	2
	RN55C6191F		/					RES R207,243	2
375									
	RN55C2261F		/					RES R234,235	2
	RN55C1472F		/					RES R221	1
	RN55C75R0F		/					RES R247	1
380	RN55C3320F		/					RES R217,253	2
	RN55C5111F		/					RES R220, MIL-R-10509/7 254,255	3
385	RC076F150J		/					RES R215 MIL-R-11/8	1
		SIZE		CODE IDENT NO					
		A		06509				LM 513260	
		SCALE		REV A				SHEET 13	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
386	RN55C1001F				/			RES R222,223, 226,256,257 MIL-R-10509/7	5
390	RN55C1102F				/			RES R210,228,238, 211,261,236,259,260, 237,246,239,262	12
395	RN55C3012F				/			RES R213,252,225 227,229	5
	RN55C2152F				/			RES R221,232	2
400	RN55C----F				/			RES R204,240 S.I.T. ≈ 50Ω TO 1K	2
	RN55C----F				/			RES R208,244 S.I.T. ≈ 5K TO 50K	2
405	RN55C----F				/			RES R239,245, 30K TO 100K MIL-R-10509/7	2
	G2 100Ω				/			RES R219 DALE	1
410	G1 10Ω				/			RES R206,242 DALE	2
	78351-6				/			CAP C209,220 SPRAGUE	2
415	M39003/01-2098				/			CAP C208,223, MIL-C39003/1A 214 (CSR13G 104 KLV)	3
	AGS-2 -1Ω				/			RES R214,251 DALE	2
420									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV A		SHEET 14	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
421	M39003/01-2128	/						CAP C211,212 MIL-G-39003/1A 221,222 (CSR13G475KLU)	4
425	M39003/01-2095	/						CAP C219 MIL-G-39003/1A (CSR13G683KLU)	1
	M39003/01-2491	/						CAP C205A,B,215A,B (CSR13B337KPU) MIL-G-39003/1A	4
430	EMUCYKO1BT103M	/						CAP C210,200, EM711411 C233,234	4
	EMUCYKO1BT333M	/						CAP C218 EM711411	1
	CK12AX470M	/						CAP C207,217 MIL-C-11015/20	2
435	CK12AX101M	/						CAP C206,216 MIL-C-11015/20	2
	10227-NYL	/						TRANSIPAD THE MILTON ROSS CO	2
	10038-DAP	/						TRANSIPAD THE MILTON ROSS CO	4
	10034-NYL	/						TRANSIPAD THE MILTON ROSS CO	11
440	TXPO508B	/						RETAINER IERC	1
	1747-2	/						WASHER, MICA	1
	14092-5	/						WASHER, EPOXY	1
	MS51957-35	/						SCREW	10
445	MS51957-5	/						SCREW	4
	MS51957-38	/						SCREW	4
	MS51957-28	/						SCREW	4
450	MS24693-C26	/						SCREW	2
	MS24692-C38	/						SCREW	2
	MS15795-308	/						WASHER, FLAT	1
455	MS15795-302	/						WASHER, FLAT	4
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV		A		SHEET 15	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
456	MS15745-305	/						WASHER FLAT	12
	MS15745-303	/						WASHER FLAT	1
	MS35337-78	/						WASHER LOCK	1
	MS3522-79	/						WASHER LOCK	12
460	MS35649-24	/						NUT	4
	MS35649-64	/						NUT	12
	MS35650-104	/						NUT	1
	115 X .196	/						LUG ZIERICK	1
	313970-1	/						XFLIR ASSY TB9	1
465	313966-1	/						POTTING CUP TB9	1
	313966-2	/						BRD BLANK	1
	5026B	/						TERMINAL LERCO	20
	NAS43DDI-52	/						SPACER	4
	5026B	/						TERMINAL LERCO	12
470	313287-1	/						XFMR T204, 204A	2
	52134-1D	/						CORE MAG. INC	2
	313288-1	/						XFMR T205, 205A	2
	A22DI	/						CORE	2
		/						WIRE	A/R
475	MS51957-13	/						SCREW	1
	14072-2	/						WASHER	1
	25429-1-4	/						INSERT	1
	25429-4-3	/						INSERT	1
	413282-1	/						SUB CHASSIS ASSY	1
480	413282-2	/						SUB CHASSIS	1
	413282-3	/						STIFFNER	1
	MF6031-06	/						NUT ANCHOR KAYNAR	4
	MF1331-06	/						NUT ANCHOR KAYNAR	10
485	MS20426AD3	/						RIVET	8
	MS20426AD2	/						RIVET	20
	MS35337-77	/						WASHER, LOCK	4
490	MS35337-81	/						WASHER, LOCK	1
		SIZE		CODE IDENT NO					
		A		06509				LM 51222	
		SCALE			REV A			SHEET 16	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
491	313268 -1	/						CCMP ASSY TB 1	1
	313267 -1	/						BOARD ASSY TB 1	1
495	313267 -2	/						BOARD BLANK	1
	3025-B	/						TERM LERCO	48
500	3535-B	/						TERM LERCO	18
	1247-10	/						STANDOFF CAMBION	4
505									
	313261 -1	/						XFMR ASSY T301	1
	113263	/						CORE	1
510	113264	/						COIL FORM	3
	313265 -1	/						BRACKET ASSY	2
515	313265 -2	/						BRACKET	1
	MF1331-06	/						NUT-ANCHOR KAYNAR	2
	MS20426AD2	/						RIVET	4
520	213266	/						INSULATOR	A/R
525									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV		A		SHEET 17	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
526	EM710456	/						DIODE, CR300-305	6
	GFA - 4/10	/						FUSE, F307-312 BUSSMANN	6
530	- 15	/						FUSE, F320-325, F332-337	12
	- 5	/						FUSE, F344-349, F356-361	12
535	GFA - 15	/						FUSE F301-303 BUSSMANN	3
	MS51957-17	/						SCREW	4
	NAS671-C4	/						NUT	4
540	MS15795-302	/						WASHER FLAT	4
	MS25327-78	/						WASHER LOCK	4
545	#24	/						WIRE BUSS	AR
	#24 WHT	/						WIRE FLEX	AR
	TYPE RA	/						SOLDER QQ-S-571	AR
550								SN60 ORG3	
	313269-1	/						COMPASSY TBZ	1
555	313267-6	/						BRDASSY TBZ	1
	313267-7	/						BRD BLANK	1
560									
		SIZE		CODE IDENT NO				LM 51-1-1-1-1	
		A		06509					
		SCALE		REV A				SHEET 18	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
561									
	3025-B			/				TERM LERCO	48
	3535-B			/				TERM LERCO	17
565									
	1247-10			/				TERM CAMBION	4
570	313262-1			/				XMFR ASSY T302	1
	113263			/				CORE	1
	113264			/				COIL FORM	3
575									
	313265-1			/				BRACKET ASSY	2
	313265-2			/				BRACKET	1
580	MF1331-06			/				NUT ANCHOR KAYNAR	2
	MS20426AD2			/				RIVET	4
585									
	213266			/				INSULATOR	AR
590									
	EM710456			/				DIODE CR 306-311	6
595									
		SIZE		CODE IDENT NO					
		A		06509		LM 313260			
		SCALE		REV		A		SHEET 19	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
596	GFA - 4/10	/						FUSE F313-316,318,319,BUSSMANN	6
	-15	/						FUSE F326-331, F338-343	12
600	-5	/						FUSE F350-355, F362-367	12
	GFA -15	/						FUSE F304-306 BUSSMANN	3
605	MS51957-17	/						SCREW	4
	NAS671-C4	/						NUT	4
	MS15795-303	/						WASHER-FLAT	4
610	MS35337-78	/						WASHER-LOCK	4
	#24	/						WIRE BUSS	AR
615	#24 WHT	/						WIRE-FLEX	AR
	TYPE RA	/						SOLDER QQ-S-571 SN600263	AR
620									
	313969-1	/						XFMR ASSY TB-11	1
	313968-1	/						POTTING CUP	1
625	313968-2	/						CUP	1
	313968-3	/						BASE	1
630	NAS43DDI-60	/						SPACER	4
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV		A		SHEET 20	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
631									
	5026B		/				TERM	LERCO	16
635	213973		/				XMFR T304		1
	52061-1A		/				CORE	MAG INC	3
640									
	213974		/				XMFR T306		1
	52061-1A		/				CORE	MAG INC	3
645									
	#24 BUSS		/				WIRE		A/R
650									
	313969-2		/				XMFR ASSY TB12		1
	313968 -1		/				POTTING CUP		1
655	313968 -2		/				CUP		1
	313968 -3		/				BASE		1
	NAS43DDI-60		/				SPACER		4
660									
	5026B		/				TERMINAL	LERCO	16
665									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV		A	
						SHEET		21	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
666									
	213973	/						XMFR T305	1
	52061-1A	/						CORE MAG INC	3
670									
	213974	/						XMFR T307	1
	52061-1A	/						CORE MAG INC	3
675									
	#24 BUSS	/						WIRE	A/R
680									
	413254 -1	/						MOTOR ASSY	1
	413252 -1	/						MOTOR BRACKET ASSY	1
685	413252 -2	/						BRACKET	1
	NAS10683C06M	/						NUT PLATE	4
	MS20426ADZ	/						RIVET	8
690									
	B18808	/						MOTOR M201,201A	2
								[2] A.W. HAYDON	
	177SJ	/						POT 1K Ω 13/4W S.TURN	2
695								1/8X3/8 SHAFT R263,265	
		/						[2] COMPUTER INSTR CO.	
700									
		SIZE		CODE IDENT NO					
		A		06509				LM 512-200	
		SCALE		—				REV A	
								SHEET 22	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
666									
	213973	/						XMFR T305	1
	52061-1A	/						CORE MAG INC	3
670									
	213974	/						XMFR T307	1
	52061-1A	/						CORE MAG INC	3
675									
	#24 BUSS	/						WIRE	A/R
680									
	413254 -1	/						MOTOR ASSY	1
	413252 -1	/						MOTOR BRACKET ASSY	1
685	413252 -2	/						BRACKET	1
	NAS1063C06M	/						NUT PLATE	4
	MS20426ADZ	/						RIVET	8
690									
	B18808	/						MOTOR M201,201A	2
								[2] A.W. HAYDON	
	1775J	/						POT 1K 2 1/2 W 5 TURN	2
695		/						1/8 X 3/8 SHAFT R263,265	
		/						[2] COMPUTER INSTR CO	
700									
		SIZE		CODE IDENT NO					
		A		06509		LM 513200			
		SCALE		REV		A		SHEET 22	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
701	313253-1	/						COMPONENT ASSY TB7	1
	313253 -2	/						TERM BRD ASSY	1
705	313253 -3	/						BRD BLANK	1
	313253 -4	/						INSULATOR	1
710	3025B	/						TERMINAL LERCO	24
	RN55C----F	/						RES R258 S.I.T. ≈ 50Ω TO 250Ω MIL-R-10509/7	1
	RN55C1102K	/						RES R233,230 MIL-R-10509/7	2
715	GI79430	/						DIODE-ZENER CR229 TRW	1
	AFIN645	/						DIODE CR225,226,227 228,225A,226A, 227A, & 228A MIL-S-19500/240	8
720	#246A	/						WIRE BUSS QQ-W-343 TYPES	A/R
725	T7-1	/						COUPLING PIC DESIGN I CORP	2
	MS51957-29	/						SCREW	4
730	MS24693-C6	/						SCREW	3
	MS35337-79	/						WASHER-LOCK	4
735									
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV		A		SHEET 23	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY. REQ
		1	2	3	4	5	6		
736	MS35327-78	/						WASHER-LOCK	1
	MS15795-305	/						WASHER-FLAT	4
740	MS35649-44	/						NUT	2
	MS35649-64	/						NUT	4
745	TRT24(7)U-9	/						WIRE MIL-W-16373TYPEA/R	
	AF IN 645	/						DIODE CRI,4 MIL-S-19500/240	2
	X N-407	/						RELAY HARTMAN ELECT	1
750								KI, MFG, CO.	
	NAS1652R18B32PN	/						CONN J1	1
	NAS1652R16B26PN	/						CONN J2	1
755	NAS1652R10B6SN	/						CONN J3	1
	413257-1	/						TERM BLOCK ASSY J4	1
760	413257-2	/						TERM BLOCK	1
	1629-4-01	/						STUD. CAMBION	20
765	AN316-C4	/						NUT	20
	213256-1	/						BUS STRAP	2
	NO.115 H.250	/						LUG, TERM ZIERICK	4
	313256-2	/						BUS STRAP	1
770	EM77308-4	/						CAPACITOR, 2.0uf 100V, C29 C30	2
		SIZE		CODE IDENT NO					
		A		06509		LM 513-200			
		SCALE		REV		A		SHEET 24	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
771	413965-1	/						COMP ASSY TB8	1
	413972-1	/						BOARD ASSY	1
775	413972-2	/						BOARD BLANK	1
	413972-3	/						INSULATOR	1
	413972-4	/						HEATSINK	1
780									
	3025-B	/						TERMINAL LERCO	102
	4535-B	/						↑	10
785	5026-B	/						↓ TERMINAL LERCO	8
	MS20426-AD4	/						RIVET	5
790									
	AN743-BC13R	/						BRACKET	1
	313285-1	/						XMFR & CUP ASSY T201	1
	313285-2	/						XMFR ASSY T201	1
795	52033-1D	/						CORE MAG INC	1
	313285-5	/						CUP ASSY	1
	313286-6	/						CUP	1
800	5025-A	/						TERM	12
	NAS43DD0-40	/						SPACER	1
	213976	/						XMFR T303	1
805	52056-1A	/						CORE MAG INC	3
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		—		REV A		SHEET 25	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY, REQ
		1	2	3	4	5	6		
806									
	EM 710456	/						DIODE CR 366,367	2
810	JAN IN 752 A	/						DIODE CR 360,362	
								MIL-S-19500/127	2
	G9-7300	/						DIODE, ZENER CR 364,365 IRC	2
815									
	AFING 45	/						DIODE CR 201-205,207-210	
								MIL-S-19500/240	9
820									
	JAN IN 2984 B	/						DIODE, ZENER CR 232	
								MIL-S-19500/272	1
	GI 79466	/						DIODE CR 245,246,47,48	4
825									
	EM 78324 U	/						TSTR Q 303,307,313,320	4
830									
	EM 73531 U	/						TSTR Q 304,308-312,318,319	8
	EM 711347	/						TSTR Q1,11 TI	2
835									
	EM 79451	/						TSTR Q2,12 SOLITRON	2
840	EM 74709 U	/						TSTR Q 300,316,317,323	4
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV A		SHEET 26			

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
841	GI 73531 H	/						TSTR Q224 RAYTHEON	1
	GI 78324	/						TSTR Q201,202 SOLITRON	2
845	GI 78324 H1	/						TSTR Q223	1
	AGS-3-1K	/						RES R307,316 DALE	2
850	AGS-1-1K	/						RES R336,325 DALE	2
	AGS-1-3K	/						RES R326,337 DALE	2
855	AGS-3-5K	/						RES R305,306 DALE	2
	GI -20Ω	/						RES R270 DALE	1
860	AGS-5-5Ω	/						RES R271 DALE	1
	AGS-5-2Ω	/						RES R1,27 DALE	2
	AGS-3-1K	/						RES R309,318 DALE	2
865	GZ -300Ω	/						RES. R272 DALE	1
	AGS-3-S.I.T.	/						RES. ≈ 7K R331 DALE	1
	AGS-3-S.I.T.	/						RES ≈ 4K R320 DALE	1
870	RN55C1001F	/						RES R2,28,341,342,314,317, R321,330 MIL-R-10509/7	8
	RN55C3321F	/						RES R343,344 MIL-R-10509/7	2
875									
		SIZE		CODE IDENT NO		LM 513260			
		A		06509					
		SCALE		REV A		SHEET 27			

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY. REQ
		1	2	3	4	5	6		
876									
	RN55C2491F	/						RES R302,311 MIL-R-10509/7	2
	RN55C2051F	/						RES R345-348	4
880									
	RN55C----F	/						RES R303,312 S.I.T. ≅ 1.1K	2
	RN55C1002F	/						RES R3,29 MIL-R-10509/7	2
885									
	RC07GF301J	/						RES R202,203 MIL-R-11/8	2
	RC07GF472J	/						RES R201 MIL-R-11/8	1
890									
	RN55C4870F	/						RES R319,332 MIL-R-10509/7	2
	EM710454H-12	/						CAP C201-204,232	5
	EMUCYK01BT103M	/						CAP C300,301 EM711411	2
895									
	25429-4-4	/						INSERT	1
	1747-2	/						WASHER-MICA	1
900	14092-5	/						WASHER-EPOXY	1
	NAS620A10	/						WASHER-FLAT	2
	MS35337-81	/						WASHER-LOCK	2
905									
	MS15795-303	/						WASHER-FLAT	1
	NAS671-C10	/						NUT	2
910	MS21043-04	/						NUT	1
		SIZE		CODE IDENT NO					
		A		06509		LM 513260			
		SCALE		REV A		SHEET 28			




ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
911									
	MS24693-C10	/						SCREW	1
	BBD-625-062	/						WASHER-INSULATOR	
915								BRUSH BERYLLIUM	2
	115 X .196	/						LUG ZIERICK	1
	10038-DAP	/						TRANSIPAD THE MILTON ROSS CO	17
920									
	10018-DAP	/						TRANSIPAD THE MILTON ROSS CO	2
	CKR06BX104KP	/						CAPACITOR, C302-304, MIL-C-39014/2	3
								.1uf 100V	
925									
930									
935									
	S3420(IN3968)	/						DIODE CR312-335 SYNTRON	24
	S2120(IN3964)	/						DIODE CR336-359 SYNTRON	24
940									
	RN55C4870F	/						RES R308,315 MIL-R-10509/7	2
945									
		SIZE		CODE IDENT NO		LM 513260			
		A		06509					
		SCALE		—		REV A		SHEET 29	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY. REQ
		1	2	3	4	5	6		
946									
	EM77684U	/						TCR Q301 302,305 306,314,315 321,322	8
950	RH-25 0.6Ω	/						RES K301,304,334 340,310,313 323,329 DALE	8
	MS51957-28	/						SCREW	37
955									
	MS51957-16	/						SCREW	8
	MS24693-C29	/						SCREW	24
960	MS51957-8	/						SCREW	8
	25429-6	/						INSERT	8
965	25429-5	/						INSERT	24
	25429-4	/						INSERT	24
	BBW-800-320-60	/						WASHER BRUSH BERYLLIUM	8
970									
	1747-1	/						WASHER, MICA	24
	1747-2	/						WASHER, MICA	24
975	NAS671-C2	/						NUT	8
	MS21043-5	/						NUT-LOCK	8
	MS21043-4	/						NUT-LOCK	24
980	MS21043-3	/						NUT-LOCK	24
		SIZE		CODE IDENT NO					
		A		06509		LM 51323U			
		SCALE		REV		A		SHEET 30	

ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO.	QTY REQ
		1	2	3	4	5	6		
981	MS24693-C30	/						SCREW	6
	MS21043-06	/						NUT-LOCK	26
985	513250 -1	/						BASE ASSY	1
	513250 -2	/						BASE BRAZE ASSY	1
990	MF6031-06	/						NUT ANCHOR KAYNAR	3
	MS20470AD3-	/						RIVET	6
995	MF1331-06	/						NUT-ANCHOR KAYNAR	34
	MS20426AD2-	/						RIVET	68
1000	F-440-2	/						NUT-CLINH PEM	8
	513255 -1	/						COVER ASSY	1
	513255 -2	/						COVER	1
1005	PA6368	/						CHANNEL PIONEER	4
	115 X.250	/						LUG ZIERICK	28
	115 X.196	/						LUG ZIERICK	28
1010	27999C06-22	/						SCREW	8
	MS15795-305	/						WASHER-FLAT	20
	NAS620A2	/						WASHER-FLAT	8
1015									
		SIZE		CODE IDENT NO					
		A		06509				LM 513260	
		SCALE		REV A				SHEET 3	


ITEM	PART NUMBER	ASSY LEVEL						DESCRIPTION, SYM, SPEC, CODE IDENT NO	QTY REQ
		1	2	3	4	5	6		
1016									
	14092-5	/						WASHER - EPOXY	24
1020	14092-6	/						WASHER - EPOXY	24
	14092-7	/						WASHER - EPOXY	8
1025	MS 35337-77	/						WASHER - LOCK	8
	MS 51957-30	/						SCREW	3
1030	313975	/						NAME PLATE	1
	NAS 1665-10	/						BACK SHELL	1
	NAS 1665-16	/						BACK SHELL	1
	NAS 1665-18	/						BACK SHELL	1
1035									
	REF BATTERY							ASSY	
	11991	/						BATTERY ASSY	2
1040								25 XYS 85 (S)	
								YARDNEY ELECT	
								CORP	
	A-50-100	/						SHUNT 100 MV	
1045								EMPRO MFG CO	2
	35TD25-SK	/						THERMISTOR RT1, RT2, R269,	4
								R298 GULTON	
1050									
		SIZE		CODE IDENT NO					
		A		06509				LM 513260	
		SCALE		REV A				SHEET 32	

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED



413249

QTY REQD	PART NUMBER	DESCRIPTION	CODE BOOK	SPECIFICATION	MATERIAL	ITEM NO.
LIST OF MATERIAL						
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES ON FRACTIONS DECIMALS ANGLES 1/16 1/32 1/64 1/8 1/4 1/2 3/4 1 1 1/2 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000 1001 1002 1003 1004 1005 1006 1007 1008 1009 1010 1011 1012 1013 1014 1015 1016 1017 1018 1019 1020 1021 1022 1023 1024 1025 1026 1027 1028 1029 1030 1031 1032 1033 1034 1035 1036 1037 1038 1039 1040 1041 1042 1043 1044 1045 1046 1047 1048 1049 1050 1051 1052 1053 1054 1055 1056 1057 1058 1059 1060 1061 1062 1063 1064 1065 1066 1067 1068 1069 1070 1071 1072 1073 1074 1075 1076 1077 1078 1079 1080 1081 1082 1083 1084 1085 1086 1087 1088 1089 1090 1091 1092 1093 1094 1095 1096 1097 1098 1099 1100 1101 1102 1103 1104 1105 1106 1107 1108 1109 1110 1111 1112 1113 1114 1115 1116 1117 1118 1119 1120 1121 1122 1123 1124 1125 1126 1127 1128 1129 1130 1131 1132 1133 1134 1135 1136 1137 1138 1139 1140 1141 1142 1143 1144 1145 1146 1147 1148 1149 1150 1151 1152 1153 1154 1155 1156 1157 1158 1159 1160 1161 1162 1163 1164 1165 1166 1167 1168 1169 1170 1171 1172 1173 1174 1175 1176 1177 1178 1179 1180 1181 1182 1183 1184 1185 1186 1187 1188 1189 1190 1191 1192 1193 1194 1195 1196 1197 1198 1199 1200 1201 1202 1203 1204 1205 1206 1207 1208 1209 1210 1211 1212 1213 1214 1215 1216 1217 1218 1219 1220 1221 1222 1223 1224 1225 1226 1227 1228 1229 1230 1231 1232 1233 1234 1235 1236 1237 1238 1239 1240 1241 1242 1243 1244 1245 1246 1247 1248 1249 1250 1251 1252 1253 1254 1255 1256 1257 1258 1259 1260 1261 1262 1263 1264 1265 1266 1267 1268 1269 1270 1271 1272 1273 1274 1275 1276 1277 1278 1279 1280 1281 1282 1283 1284 1285 1286 1287 1288 1289 1290 1291 1292 1293 1294 1295 1296 1297 1298 1299 1300 1301 1302 1303 1304 1305 1306 1307 1308 1309 1310 1311 1312 1313 1314 1315 1316 1317 1318 1319 1320 1321 1322 1323 1324 1325 1326 1327 1328 1329 1330 1331 1332 1333 1334 1335 1336 1337 1338 1339 1340 1341 1342 1343 1344 1345 1346 1347 1348 1349 1350 1351 1352 1353 1354 1355 1356 1357 1358 1359 1360 1361 1362 1363 1364 1365 1366 1367 1368 1369 1370 1371 1372 1373 1374 1375 1376 1377 1378 1379 1380 1381 1382 1383 1384 1385 1386 1387 1388 1389 1390 1391 1392 1393 1394 1395 1396 1397 1398 1399 1400 1401 1402 1403 1404 1405 1406 1407 1408 1409 1410 1411 1412 1413 1414 1415 1416 1417 1418 1419 1420 1421 1422 1423 1424 1425 1426 1427 1428 1429 1430 1431 1432 1433 1434 1435 1436 1437 1438 1439 1440 1441 1442 1443 1444 1445 1446 1447 1448 1449 1450 1451 1452 1453 1454 1455 1456 1457 1458 1459 1460 1461 1462 1463 1464 1465 1466 1467 1468 1469 1470 1471 1472 1473 1474 1475 1476 1477 1478 1479 1480 1481 1482 1483 1484 1485 1486 1487 1488 1489 1490 1491 1492 1493 1494 1495 1496 1497 1498 1499 1500 1501 1502 1503 1504 1505 1506 1507 1508 1509 1510 1511 1512 1513 1514 1515 1516 1517 1518 1519 1520 1521 1522 1523 1524 1525 1526 1527 1528 1529 1530 1531 1532 1533 1534 1535 1536 1537 1538 1539 1540 1541 1542 1543 1544 1545 1546 1547 1548 1549 1550 1551 1552 1553 1554 1555 1556 1557 1558 1559 1560 1561 1562 1563 1564 1565 1566 1567 1568 1569 1570 1571 1572 1573 1574 1575 1576 1577 1578 1579 1580 1581 1582 1583 1584 1585 1586 1587 1588 1589 1590 1591 1592 1593 1594 1595 1596 1597 1598 1599 1600 1601 1602 1603 1604 1605 1606 1607 1608 1609 1610 1611 1612 1613 1614 1615 1616 1617 1618 1619 1620 1621 1622 1623 1624 1625 1626 1627 1628 1629 1630 1631 1632 1633 1634 1635 1636 1637 1638 1639 1640 1641 1642 1643 1644 1645 1646 1647 1648 1649 1650 1651 1652 1653 1654 1655 1656 1657 1658 1659 1660 1661 1662 1663 1664 1665 1666 1667 1668 1669 1670 1671 1672 1673 1674 1675 1676 1677 1678 1679 1680 1681 1682 1683 1684 1685 1686 1687 1688 1689 1690 1691 1692 1693 1694 1695 1696 1697 1698 1699 1700 1701 1702 1703 1704 1705 1706 1707 1708 1709 1710 1711 1712 1713 1714 1715 1716 1717 1718 1719 1720 1721 1722 1723 1724 1725 1726 1727 1728 1729 1730 1731 1732 1733 1734 1735 1736 1737 1738 1739 1740 1741 1742 1743 1744 1745 1746 1747 1748 1749 1750 1751 1752 1753 1754 1755 1756 1757 1758 1759 1760 1761 1762 1763 1764 1765 1766 1767 1768 1769 1770 1771 1772 1773 1774 1775 1776 1777 1778 1779 1780 1781 1782 1783 1784 1785 1786 1787 1788 1789 1790 1791 1792 1793 1794 1795 1796 1797 1798 1799 1800 1801 1802 1803 1804 1805 1806 1807 1808 1809 1810 1811 1812 1813 1814 1815 1816 1817 1818 1819 1820 1821 1822 1823 1824 1825 1826 1827 1828 1829 1830 1831 1832 1833 1834 1835 1836 1837 1838 1839 1840 1841 1842 1843 1844 1845 1846 1847 1848 1849 1850 1851 1852 1853 1854 1855 1856 1857 1858 1859 1860 1861 1862 1863 1864 1865 1866 1867 1868 1869 1870 1871 1872 1873 1874 1875 1876 1877 1878 1879 1880 1881 1882 1883 1884 1885 1886 1887 1888 1889 1890 1891 1892 1893 1894 1895 1896 1897 1898 1899 1900 1901 1902 1903 1904 1905 1906 1907 1908 1909 1910 1911 1912 1913 1914 1915 1916 1917 1918 1919 1920 1921 1922 1923 1924 1925 1926 1927 1928 1929 1930 1931 1932 1933 1934 1935 1936 1937 1938 1939 1940 1941 1942 1943 1944 1945 1946 1947 1948 1949 1950 1951 1952 1953 1954 1955 1956 1957 1958 1959 1960 1961 1962 1963 1964 1965 1966 1967 1968 1969 1970 1971 1972 1973 1974 1975 1976 1977 1978 1979 1980 1981 1982 1983 1984 1985 1986 1987 1988 1989 1990 1991 1992 1993 1994 1995 1996 1997 1998 1999 2000 2001 2002 2003 2004 2005 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042 2043 2044 2045 2046 2047 2048 2049 2050 2051 2052 2053 2054 2055 2056 2057 2058 2059 2060 2061 2062 2063 2064 2065 2066 2067 2068 2069 2070 2071 2072 2073 2074 2075 2076 2077 2078 2079 2080 2081 2082 2083 2084 2085 2086 2087 2088 2089 2090 2091 2092 2093 2094 2095 2096 2097 2098 2099 2100 2101 2102 2103 2104 2105 2106 2107 2108 2109 2110 2111 2112 2113 2114 2115 2116 2117 2118 2119 2120 2121 2122 2123 2124 2125 2126 2127 2128 2129 2130 2131 2132 2133 2134 2135 2136 2137 2138 2139 2140 2141 2142 2143 2144 2145 2146 2147 2148 2149 2150 2151 2152 2153 2154 2155 2156 2157 2158 2159 2160 2161 2162 2163 2164 2165 2166 2167 2168 2169 2170 2171 2172 2173 2174 2175 2176 2177 2178 2179 2180 2181 2182 2183 2184 2185 2186 2187 2188 2189 2190 2191 2192 2193 2194 2195 2196 2197 2198 2199 2200 2201 2202 2203 2204 2205 2206 2207 2208 2209 2210 2211 2212 2213 2214 2215 2216 2217 2218 2219 2220 2221 2222 2223 2224 2225 2226 2227 2228 2229 2230 2231 2232 2233 2234 2235 2236 2237 2238 2239 2240 2241 2242 2243 2244 2245 2246 2247 2248 2249 2250 2251 2252 2253 2254 2255 2256 2257 2258 2259 2260 2261 2262 2263 2264 2265 2266 2267 2268 2269 2270 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282 2283 2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302 2303 2304 2305 2306 2307 2308 2309 2310 2311 2312 2313 2314 2315 2316 2317 2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330 2331 2332 2333 2334 2335 2336 2337 2338 2339 2340 2341 2342 2343 2344 2345 2346 2347 2348 2349 2350 2351 2352 2353 2354 2355 2356 2357 2358 2359 2360 2361 2362 2363 2364 2365 2366 2367 2368 2369 2370 2371 2372 2373 2374 2375 2376 2377 2378 2379 2380 2381 2382 2383 2384 2385 2386 2387 2388 2389 2390 2391 2392 2393 2394 2395 2396 2397 2398 2399 2400 2401 2402 2403 2404 2405 2406 2407 2408 2409 2410 2411 2412 2413 2414 2415 2416 2417 2418 2419 2420 2421 2422 2423 2424 2425 2426 2427 2428 2429 2430 2431 2432 2433 2434 2435 2436 2437 2438 2439 2440 2441 2442 2443 2444 2445 2446 2447 2448 2449 2450 2451 2452 2453 2454 2455 2456 2457 2458 2459 2460 2461 2462 2463 2464 2465 2466 2467 2468 2469 2470 2471 2472 2473 2474 2475 2476 2477 2478 2479 2480 2481 2482 2483 2484 2485 2486 2487 2488 2489 2490 2491 2492 2493 2494 2495 2496 2497 2498 2499 2500 2501 2502 2503 2504 2505 2506 2507 2508 2509 2510 2511 2512 2513 2514 2515 2516 2517 2518 2519 2520 2521 2522 2523 2524 2525 2526 2527 2528 2529 2530 2531 2532 2533 2534 2535 2536						





NOTES



1 TEMP HEAT SIGNAL LAST DOWN ARE IN 42 CBI, CRASH KIP 1
FF 42 489


2 COMPONENT SYMBOLS O FFA6 Q23

[illegible]



TR POWER SUPPLY





Q	PC30C480F	RES		DEL E W507F	R308 J13
1	WAS66E 18	BACK SHELL			
1	WAS166F-1G	BACK SHELL			
1	WAS166S-10	BACK SHELL			
1	313975	WASHER PLAT			
3	WAS166H-90	SCREW			
3	WAS3827 77	WASHER LOCK			
3	WAS632-A2	WASHER PLAT			
3	WAS1575S-305	WASHER PLAT			
3	272930C08F	SCREW			
20	15X 736	WLG	77963		ZIERCKX
20	15X 730	WLG	77963		ZIERCKX
1	513253 1	COVER			
1	513260 41	BASE ASSY			
2	WAS10043-06	NUT LOCK			
4	WAS1491-C40	SCREW			
24	WAS10043-9	NUT LOCK			
4	WAS12043 4	NUT LOCK			
4	WAS12043 5	NUT LOCK			
5	16092 7	WASHER BODY			
24	16092 8	WASHER BODY			
4	16092 9	WASHER BODY			
24	1747 2	WASHER WEA			
24	1747 1	WASHER WEA			
3	BBW 800500-80	WASHER WEA			
24	25429 4	NSERT			
24	25429 5	NSERT			
3	25429 6	NSERT			
4	WAS1957 5	SCREW			
2	AF1N443	DIODE			
4	WAS371 C2	NUT			
24	WAS1493-C29	SCREW			
4	WAS957 16	SCREW			
27	WAS1957 Z5	SCREW			
3	RAH 25 00A	RES			
3	EMT7684U	T8TR			
24	3212C0195441	DIODE	81093	CA336 322	SVLTRON
24	3242C0195441	DIODE	81093	CA336 322	SVLTRON
1	43968-1	COMPASSION			
1	418257-1	TEST WCKR			
1	WAS4622082PU	CONN			
1	WAS4622082PU	CONN			
1	WAS46221832PU	CONN			
1	X11-407	RELAY	706L	X1	
1	418364 1	MOTOR ASSY			
1	515698 2	COMP ASSY			
1	515698 1	COMP ASSY			
1	518269 1	COMP ASSY			
1	518269 1	COMP ASSY			
1	418263-1	SH CHASIS ARM			
		ASSY			

4. WORKMANSHIP PER 73400
5. ASSEMBLE PER 73422
6. ASSEMBLE PER 74446
7. ASSEMBLE PER 74447

[illegible]

APPENDIX II

EMPS252 TEST PROCEDURE

AND

OPERATIONAL TEST DATA

↓ REVISIONS

SYM	DESCRIPTION	DATE	APPROVED
A	FORMAL RELEASE	1-6-69	K. Jacobs

DATE 12/20/68

DR C. Ghiselline

CHK

ENGR *H. Gross*

MECH ENGR

REL ENGR

PROJ ENGR

APPD *M. Kruse*

APPD

Gulton Industries, Inc.
HAWTHORNE, CALIFORNIA

TEST PROCEDURE FOR EMPS252
BRAYTON CYCLE D.C. POWER SYSTEM

CODE IDENT NO.

06509

SIZE

A

713331

SCALE

SHEET 1 of 21

1.0 INTRODUCTION

The D.C. power system for the Brayton Cycle alternator provides +28VDC and -28VDC from transformer rectifiers or from two batteries. In addition the system has charge control logic ampere hour meters, voltage, temperature, current and state of charge telemetry.

This series of tests will verify that system meets certain minimum performance requirements at various temperature.

2.0 SYSTEM DESCRIPTION

Page 4 through 16 final report.

3.0 TEST OBJECTIVES

The following tests will verify that the system will operate as designed. Criteria for this verification are based on bread-board performance data¹ and on calculations taking into account guaranteed component limitations and previous experience with these components. Complete test records will detail system performance against the worst expected variations. In addition telemetry calibration curves will be provided where necessary.

4.0 LIST OF APPLICABLE DOCUMENTS

- 4.1 NASA Contract NAS3-10936, Exhibit B. Scope of work as amended.
- 4.2 Test Fixture Schematic EM313290.

CODE IDENT NO	SIZE		
06509	A	713331	
SCALE		SHEET	2

5.0 LIST OF TEST EQUIPMENT, OR SIMILAR

- 5.1 Oscilloscope, Tektronix 531
- 5.2 Digital Voltmeter, HP3440A
- 5.3 Temperature Chamber, Bemco
- 5.4 Multimeter, Triplet 630A
- 5.5 Power Supply, Power Design 4005
- 5.6 Power Supply, Engineered Magnetics 50 Amp
- 5.7 Digital Frequency Counter, HP5243L
- 5.8 Ammeter, Weston 0-10 Amp
- 5.9 2 ea. 3.5 ohm, 500W. Power Resistors
- 5.10 Test Fixture, EM 313290
- 5.11 Power Supply, General Resistance No. DAS-46L
- 5.12 Resistance Decade Box, GR Type 1432-N

6.0 TEST SEQUENCE

All tests are at room temperature and atmospheric pressure unless otherwise noted.

6.1 General Procedures

- 6.1.1 Record all measurements on the test record form and check that data are within the limits specified.
- 6.1.2 Use Digital Volt Meter for all voltage adjustments and readings unless otherwise noted.
- 6.1.3 Positive Side Transformer, Rectifier, Logic and Charger Tests.

CODE IDENT NO. 06509	SIZE A	713331
SCALE	SHEET 3	

6.1.3.1 Connect the unit under test to the test fixture and its positive battery connection to the 0-10A ammeter in series with the 3.5 ohm power resistor to ground. Connect the 0-50A test supply in series with a silicon diode, having a rating of at least 6A and 50V, across the 3.5 ohm power resistor in order to simulate the battery voltage when the charger is off. Set the supply for 21 to 26 volts. Use this method of battery voltage simulation for the remainder of the test procedure whenever the use of the 3.5 or 7 ohm power resistor is called for.

Connect a test lead from Pin V of J1 to Pin 10 of J4, and another test lead from Pin X of J1 to Pin 11 of J4. These two leads must be connected whenever the unit is operated without the two batteries and their current shunts connected.

Connect the 0-40V test supply for a positive voltage of 39.5V between test point TB9-36 and ground. Turn on the AC generator, then set the test fixture for relay open and charger off. Record the voltage at Pin 1 of J4 and record the current readings for the following conditions:

- 6.1.3.2 Charger Command- Off
- 6.1.3.3 Charger Command- On
- 6.1.3.4 Charger Command- Auto
- 6.1.3.5 Re-adjust the test supply to 28.5 volts
- 6.1.3.6 Charger Command- On
- 6.1.3.7 Charger Command- Off

CODE IDENT NO 06509	SIZE A	713331
SCALE	SHEET 4	

- ↓
- 6.1.3.8 Change the 3.5 ohm power resistor to 7 ohms, re-adjust the test supply to 37.5 volts. Set Charger Command to ON and check that ammeter reads more than 5.0 amperes.
- 6.1.3.9 Set Charger Command to Auto and record the current reading.
- 6.1.3.10 Slowly increase the test supply voltage until the previous 3-5 ampere reading drops suddenly to less than 0.1 ampere. Record the test supply voltage for this condition and the following:

CODE IDENT NO. 06509	SIZE A	713331
SCALE		SHEET 4A

- 6.1.3.11 Slowly decrease the test supply voltage until the current increases suddenly to 3-5 amperes.
- 6.1.3.12 With the multimeter on the 12VDC range, check to see that the voltage at test point TB9-30 is less than ± 0.5 volts.
- 6.1.3.13 Continue to slowly decrease the test supply voltage until the 3-5 ampere reading increases suddenly to more than 5.0 amperes.
- 6.1.3.14 Slowly increase the test supply voltage until the current drops suddenly back to 3-5 amperes.
- 6.1.3.15 Measure and record the voltage at test point TB9-25.
- 6.1.3.16 Increase the test supply voltage to 39.5 volts and then slowly decrease it to 33 volts, checking that the current now reads less than 0.1 amperes.
- 6.1.3.17 Set Charger Command to On and then back to Auto, checking that the current is now more than 5.5 amperes.
- 6.1.3.18 Connect the resistance decade box to pins G and H of J1. Decrease the resistance until the current drops to less than 0.1 amperes, and record this value of resistance.
- 6.1.3.19 Increase the resistance until the current returns to more than 5.5 amperes, and record this value of resistance. Turn off the AC generator.

CODE IDENT NO. 06509	SIZE A	713331	
SCALE		SHEET	5

6.1.4 Negative Side Transformer, Rectifier, Logic and Charger Tests.

- 6.1.4.1 Connect the 0-10A ammeter in series with the 3.5 ohm power resistor from the units negative battery connection to ground. Connect the 0-40V test supply for a negative voltage of 39.5V between test point TB9-34 and ground. Turn on the AC generator, record the voltage at Pin 2 of J4, and the current readings for the following conditions:
- 6.1.4.2 Charger Command - Off
- 6.1.4.3 Charger Command - On
- 6.1.4.4 Charger Command - Auto
- 6.1.4.5 Re-adjust the test supply to 28.5 volts.
- 6.1.4.6 Charger Command - On
- 6.1.4.7 Charger Command - Off
- 6.1.4.8 Change the 3.5 ohm power resistor to 7 ohms, re-adjust the test supply to 37.5 volts. Set Charger Command to On and check that ammeter reads more than 5.0 amperes.
- 6.1.4.9 Set Charger Command to Auto and record the current reading.
- 6.1.4.10 Slowly increase the test supply voltage until the previous 3-5 ampere reading drops suddenly to less than 0.1 ampere. Record the test supply voltage for this condition and the following:
- 6.1.4.11 Slowly decrease the test supply voltage until the current increases suddenly to 3-5 amperes.

CODE IDENT NO. 06509	SIZE A	713331
SCALE		SHEET 6

- 6.1.4.12 With the multimeter on the 12VDC range, check to see that the voltage at test point TB9-29 is less than ± 0.5 volts.
- 6.1.4.13 Continue to slowly decrease the test supply voltage until the 3-5 ampere reading increases suddenly to more than 5.0 amperes.
- 6.1.4.14 Slowly increase the test supply voltage until the current drops suddenly back to 3-5 amperes.
- 6.1.4.15 Measure and record the voltage at test point TB9-26.
- 6.1.4.16 Increase the test supply voltage to 39.5 volts and then slowly decrease it to 33 volts, checking that the current now reads less than 0.1 amperes.
- 6.1.4.17 Set Charger Command to On and then back to Auto, checking that the current is now more than 5.0 amperes.
- 6.1.4.18 Connect the resistance decade box to pins E and F of J1. Decrease the resistance until the current drops to less than 0.1 amperes, and record this value of resistance.
- 6.1.4.19 Increase the resistance until the current returns to more than 5.0 amperes, and record this value of resistance. Turn off the AC generator.

CODE IDENT NO 06509	SIZE A	713331
SCALE		SHEET 7

6.1.5 Negative Side Ampere Hour Meter Tests

- 6.1.5.1 Connect the millivolt test supply for a negative voltage to pin W with respect to pin V of J1. Connect a test lead from pin V of J1 to pin 10 of J4. Connect the frequency counter to the collector of Q216A, turn on the AC generator and record the period of the pulses for the following conditions:
- 6.1.5.2 Set the test supply to 8 MV.
- 6.1.5.3 Set the test supply to 80 MV.
- 6.1.5.4 Shift the decimal point one place to the right of the reading at 80 MV (6.1.5.3) and check to see that it is within 5% of the reading at 8 MV (6.1.5.2).
- 6.1.5.5 Reverse the polarity of the millivolt supply, connect the counter to the collector of Q210A and repeat (6.1.5.2, 3 and 4), recording the data at (6.1.5.6, 7 and 8).
- 6.1.5.9 Reverse the polarity of the millivolt supply and decrease the ampere hour meter output voltage setting until the voltage at pin P of J1 is 0 volts. Turn off the millivolt supply and increase the voltage of the test supply at test point TB9-34 to -39.5 volts. Note the time when the counter starts indicating the pulse period.
- 6.1.5.10 Record the period.
- 6.1.5.11 Note the time when the counter stops indicating the pulse period. Divide the interval, in seconds, by the pulse period, in seconds and record this number.

CODE IDENT NO. 06509	SIZE A	713331
SCALE		SHEET 8

- 6.1.5.12 Record the voltage at pin P of J1.
- 6.1.5.13 Slowly decrease the test supply voltage at test point TB9-34 to 37.5 volts, checking that the current now reads' less than 0.1 amperes.
- 6.1.5.14 Turn on the millivolt supply, decreasing the amp hour meter setting until the current increases suddenly to 3-5 amperes. At this time turn off the millivolt supply and record the voltage at pin P of J1. Turn off the AC generator.

6.1.6 Positive Side Ampere Hour Meter Tests

- 6.1.6.1 Connect the millivolt test supply for a negative voltage to pin Y with respect to pin X of J1. Connect a test lead from pin X of J1 to pin 11 of J4. Connect the frequency counter to the collector of Q216, turn on the AC generator.
- 6.1.6.2 Set the test supply to 8 MV.
- 6.1.6.3 Set the test supply to 80 MV.
- 6.1.6.4 Shift the decimal point one place to the right of the reading at 80 MV (6.1.6.3) and check to see that it is within 5% of the reading at 8 MV (6.1.6.2).
- 6.1.6.5 Reverse the polarity of the millivolt supply, connect the counter to the collector of Q210 and repeat (6.1.6.2, 3 and 4), recording the data at 6.1.6.6, 7 and 8).
- 6.1.6.9 Reverse the polarity of the millivolt supply and decrease the ampere hour meter output voltage setting until the voltage

CODE IDENT NO. 06509	SIZE A	713331
SCALE		SHEET 9

6.1.6.9 cont'd. at pin N of J1 is 0 volts. Turn off the millivolt supply and increase the voltage of the test supply at test point TB9-36 to +39.5 volts. Note the time when the counter starts indicating the pulse period.

6.1.6.10 Record the period.

6.1.6.11 Note the time when the counter stops indicating the pulse period. Divide the interval, in seconds, by the pulse period, in seconds and record this number.

6.1.6.12 Record the voltage at pin N of J1.

6.1.6.13 Connect the 0-10 ammeter in series with the 7 ohm resistor to the units positive battery connection. Slowly decrease the test supply voltage at test point TB9-36 to 37.5 volts, checking that the current now reads less than 0.1 amperes.

6.1.6.14 Turn on the millivolt supply, decreasing the amp hour meter setting until the current increases suddenly to 3-5 amperes. At this time turn off the millivolt supply and record the voltage at pin N of J1. Turn off the AC generator.

6.1.7 Relay and Time Delay Tests

6.1.7.1 Connect the test supply for a positive voltage of 30V between test point TB9-32 and ground.

Set test fixture for charger off and relay open. Connect a test lead between Pin 1 and 9 of J4, and turn on the AC generator.

CODE IDENT NO	SIZE		
06509	A	713331	
SCALE		SHEET	10

- 6.1.7.1 cont'd. Set relay to close.
- 6.1.7.2 Check that relay status is closed.
- 6.1.7.3 Set relay to Auto and check the time required for the relay to open.
- 6.1.7.4 Slowly decrease the test supply voltage until the relay closes and record this voltage.
- 6.1.7.5 Set relay to open and check that it does.
- 6.1.7.6 Slowly increase the test supply voltage until the voltage at test point TB9-28 suddenly drops to between -1 and 0 volts. Record the test supply voltage.

6.1.8 Telemetry Tests

- 6.1.8.1 Set charger to off and relay to close. Measure the voltage at pin 9 of J4 and record the ratio of this voltage to those measured at the following places:
- 6.1.8.2 Pin f of J1
- 6.1.8.3 Pin g of J1—
- 6.1.8.4 Measure the voltage at pin 10 of J4 and record the ratio of this voltage to those measured at the following places:
- 6.1.8.5 Pin e of J1
- 6.1.8.6 Pin h of J1
- 6.1.8.7 Record and graph the output voltage for each of the four current sensors on test record form, figure 1, 2, 3 and 4. Make measurements at 0, 10 and 25 amperes.

CODE IDENT NO 06509	SIZE A	713331	
SCALE		SHEET	11

6.1.8.8 Record and graph the output voltage of both battery temperature sensors on Test Record Form, Figure 5 and 6. Use the resistance decade box to simulate the thermistor resistance at each of the following temperature/resistance points:

(a) $14^{\circ}\text{F} = 27,800\Omega$

(b) $68^{\circ}\text{F} = 6,250\Omega$

(c) $122^{\circ}\text{F} = 1,798\Omega$

(d) $176^{\circ}\text{F} = 626\Omega$

(e) $194^{\circ}\text{F} = 456\Omega$

6.1. Buss and Solder Test Point TB9-31 to TB9-32, TB9-33 to TB9-34 and TB9-35 to TB9-36.

CODE IDENT NO	SIZE	
06509	A	71151
SCALE		SHEET 12

UNIT #1 , SERIAL NO. 26268

EMPS252 TEST RECORD FORM

Date MARCH 27, 1969

Technician J. MATSUMOTO

-10° F AMB
0° BASE PLATE

120° AMB
157° BASE PLATE

Test Procedure Para.	0° F	+70° F	+120° F	+160° F	Range
6.1.3.1	28.18	28.35		27.83	+27-34 Volts
6.1.3.2	✓	✓		✓	0-0.1 Amperes *
6.1.3.3	6.4	7.8		8.5	6-10 Amperes
6.1.3.4	✓	✓		✓	0-0.1 Amperes
6.1.3.5	6.4	7.9		8.5	6-10 Amperes
6.1.3.6	6.4	7.9		8.5	6-10 Amperes
6.1.3.7	✓	✓		✓	0-0.1 Amperes
6.1.3.8	✓	✓		✓	≥ 5.0 Amperes
6.1.3.9	3.4	4.1		3.7	3-5 Amperes
6.1.3.10	38.2	38.0		37.6	+37.5-39.0 Volts
6.1.3.11	31.0	30.7		30.6	+29.5-31.5 Volts
6.1.3.12	✓	✓		✓	≤ +0.5 Volts
6.1.3.13	30.6	30.3		30.1	+29-31 Volts
6.1.3.14	37.2	36.9		36.5	+36.0-38.0 Volts
6.1.3.15	41.3	41.2		41.4	+40-46 Volts
6.1.3.16	✓	✓		✓	0-0.1 Amperes
6.1.3.17	✓	✓		✓	≥ 5.0 Amperes
6.1.3.18	565	570		575	450-650 Ohms
6.1.3.19	660	667		672	500-750 Ohms
6.1.4.1	27.99	28.18		28.23	-27-34 Volts
6.1.4.2	✓	✓		✓	0-0.1 Amperes
6.1.4.3	7.8	8.3		8.7	6-10 Amperes
6.1.4.4	✓	✓		✓	0-0.1 Amperes
6.1.4.5	7.8	8.3		8.7	6-10 Amperes
6.1.4.6	7.8	8.3		8.7	6-10 Amperes
6.1.4.7	✓	✓		✓	0-0.1 Amperes
6.1.4.8	✓	✓		✓	≥ 5.0 Amperes
6.1.4.9	4.1	4.2		4.5	3-5 Amperes
6.1.4.10	37.9	38.2		38.4	-37.5-39.0 Volts

* BATTERY SIMULATOR SET AT 26V

UNIT #1, SERIAL NO. 26268

EMPS252 TEST RECORD FORM cont'd.

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.4.11	30.2	30.4		30.7	-29.5-31.5 Volts
6.1.4.12	✓	✓		✓	≤ -0.5 Volts
6.1.4.13	30.1	30.3		30.6	-29-31 Volts
6.1.4.14	36.6	36.9		37.0	36.0-38.0 Volts
6.1.4.15	41.2	41.2		41.3	-40-46 Volts
6.1.4.16	✓	✓		✓	0-0.1 Amperes
6.1.4.17	✓	✓		✓	≥ 5.0 Amperes
6.1.4.18	442	507		511	450-650 Ohms
6.1.4.19	449	606		603	500-750 Ohms
6.1.5.2	13.3	13.8		14.8	12.1-14.7 Seconds
6.1.5.3	1.32	1.34		1.40	1.21-1.47 Seconds
6.1.5.4	✓	✓		X	≤ 5%
6.1.5.6	12.5	12.9		13.0	12.1-14.7 Seconds
6.1.5.7	1.34	1.37		1.41	1.21-1.47 Seconds
6.1.5.8	X	X		X	≤ 5%
6.1.5.10	X		X	X	30-50 MS
6.1.5.11	X		X	X	5400-5900 p.f.s.
6.1.5.12	4.99	4.98		4.98	+4.8-5.1 Volts
6.1.5.13	✓	✓		✓	0-0.1 Amperes
6.1.5.14	4.48	4.47		4.48	+4.35-4.65 Volts
6.1.6.2	12.7	13.4		13.8	12.1-14.7 Seconds
6.1.6.3	1.30	1.34		1.37	1.21-1.47 Seconds
6.1.6.4	✓	✓		✓	≤ 5%
6.1.6.6	13.3	13.8		14.0	12.1-14.7 Seconds
6.1.6.7	1.32	1.36		1.40	1.21-1.47 Seconds
6.1.6.8	✓	✓		✓	≤ 5%
6.1.6.10	X		X	X	30-50MS
6.1.6.11	X		X	X	5400-5900 p.f.s.
6.1.6.12	5.03	5.06		5.07	+4.8-5.1 Volts
6.1.6.13	✓	✓		✓	0-0.1 Amperes
6.1.6.14	4.49	4.49		4.51	+4.35-4.65 Volts

UNIT #1, SERIAL NO. 26268

EMPS252 TEST RECORD FORM cont'd.


Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.7.2	✓	✓		✓	Relay Closed
6.1.7.3	4.0	4.5		4.5	3-7 Seconds, Open
6.1.7.4	24.0	24.0		24.1	+23-25 Volts
6.1.7.5	✓	✓		✓	Relay Open
6.1.7.6	25.1	25.2		25.2	+24-26 Volts
6.1.8.2	X		X	X	7.3-7.7:1
6.1.8.3	X		X	X	7.3-7.7:1
6.1.8.5	X		X	X	7.3-7.7:1
6.1.8.6	X		X	X	7.3-7.7:1

-16-

Figure 1

Positive Battery Current Sensor

Unit Serial No. 26268




-17-

Figure 2

Negative Battery Current Sensor

Unit Serial No. 26268




-18-

Figure 3

Positive T.R. Current Sensor

Unit Serial No. 2626.8




UNIT #1

⊙ = 0°F
+ = +70°F
x = +160°F

VOLTS

IT-20



AMPERES

-20-

26268
Unit Serial No.


Figure 5

Positive Battery Temperature Sensor

11-21

VOLTS


UNIT #1



-21-

Figure 6

Negative Battery Temperature Sensor

26268
Unit Serial No.

UNIT # 2, SERIAL NO. 26267

EMPS252 TEST RECORD FORM cont'd.

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.4.11		30.5			-29.5-31.5 Volts
6.1.4.12		✓			≤ -0.5 Volts
6.1.4.13		30.4			-29-31 Volts
6.1.4.14		36.5			-36.0-38.0 Volts
6.1.4.15		41.5			-40-46 Volts
6.1.4.16		✓			0-0.1 Amperes
6.1.4.17		5.5			≥ 5.0 Amperes
6.1.4.18		535			450-650 Ohms
6.1.4.19		636			500-750 Ohms
6.1.5.2		13.4			12.1-14.7 Seconds
6.1.5.3		1.35			1.21-1.47 Seconds
6.1.5.4		✓			≤ 5%
6.1.5.6		13.6			12.1-14.7 Seconds
6.1.5.7		1.30			1.21-1.47 Seconds
6.1.5.8		✓			≤ 5%
6.1.5.10	X		X	X	30-50 MS
6.1.5.11	X		X	X	5400-5900 p.f.s.
6.1.5.12		5.03			+4.8-5.1 Volts
6.1.5.13		✓			0-0.1 Amperes
6.1.5.14		4.51			+4.35-4.65 Volts
6.1.6.2		13.5			12.1-14.7 Seconds
6.1.6.3		1.35			1.21-1.47 Seconds
6.1.6.4		✓			≤ 5%
6.1.6.6		13.9			12.1-14.7 Seconds
6.1.6.7		1.38			1.21-1.47 Seconds
6.1.6.8		✓			≤ 5%
6.1.6.10	X		X	X	30-50MS
6.1.6.11	X		X	X	5400-5900 p.f.s.
6.1.6.12		4.97			+4.8-5.1 Volts
6.1.6.13		✓			0-0.1 Amperes
6.1.6.14		4.48			+4.35-4.65 Volts

EMPS252 TEST RECORD FORM

UNIT# 2, SERIAL# 26267

Date MARCH 28, 1969Technician J. MATSUMOTO

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.3.1		28.6			+27-34 Volts
6.1.3.2		✓			0-0.1 Amperes
6.1.3.3		8.3			6-10 Amperes
6.1.3.4		✓			0-0.1 Amperes
6.1.3.5		8.3			6-10 Amperes
6.1.3.6		8.3			6-10 Amperes
6.1.3.7		✓			0-0.1 Amperes
6.1.3.8		5.5			≥ 5.0 Amperes
6.1.3.9		4.3			3-5 Amperes
6.1.3.10		37.8			+37.5-39.0 Volts
6.1.3.11		30.5			+29.5-31.5 Volts
6.1.3.12		✓			≤ +0.5 Volts
6.1.3.13		30.2			+29-31 Volts
6.1.3.14		36.8			+36.0-38.0 Volts
6.1.3.15		41.4			+40-46 Volts
6.1.3.16		✓			0-0.1 Amperes
6.1.3.17		5.5			≥ 5.0 Amperes
6.1.3.18		540			450-650 Ohms
6.1.3.19		625			500-750 Ohms
6.1.4.1		28.33			-27-34 Volts
6.1.4.2		✓			0-0.1 Amperes
6.1.4.3		8.1			6-10 Amperes
6.1.4.4		✓			0-0.1 Amperes
6.1.4.5		8.1			6-10 Amperes
6.1.4.6		8.1			6-10 Amperes
6.1.4.7		✓			0-0.1 Amperes
6.1.4.8		5.5			≥ 5.0 Amperes
6.1.4.9		4.2			3-5 Amperes
6.1.4.10		38.1			-37.5-39.0 Volts

UNIT # 2, SERIAL NO. 26267

EMPS252 TEST RECORD FORM cont'd.

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.7.2		✓			Relay Closed
6.1.7.3		5			3-7 Seconds, Open
6.1.7.4		23.9			+23-25 Volts
6.1.7.5		✓			Relay Open
6.1.7.6		24.9			+24-26 Volts
6.1.8.2	X		X	X	7.3-7.7:1
6.1.8.3	X		X	X	7.3-7.7:1
6.1.8.5	X		X	X	7.3-7.7:1
6.1.8.6	X		X	X	7.3-7.7:1

-16-

Figure 1 -

Positive Battery Current Sensor

Unit Serial No. 26267




Figure 2

Negative Battery Current Sensor

Unit Serial No. 26267




Figure 3

Positive T.R. Current Sensor

Unit Serial No. 26267

VOLTS

II-28

AMPERES




Figure 4

Negative T.R. Current Sensor

Unit Serial No. 26267.




Figure 5

Positive Battery Temperature Sensor

26267
Unit Serial No.

UNIT #2




Figure 6


Negative Battery Temperature Sensor

26267
Unit Serial No.

13-11

VOLTS

UNIT #2



UNIT #3, SERIAL NO. 26269

EMPS252 TEST RECORD FORM

Date 2-21-69Technician AK

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.3.1		28.3			+27-34 Volts
6.1.3.2		✓			0-0.1 Amperes
6.1.3.3		8.2			6-10 Amperes
6.1.3.4		✓			0-0.1 Amperes
6.1.3.5		8.2			6-10 Amperes
6.1.3.6		8.2			6-10 Amperes
6.1.3.7		✓			0-0.1 Amperes
6.1.3.8		✓			≥ 5.0 Amperes
6.1.3.9		4.0			3-5 Amperes
6.1.3.10		37.7			+37.5-39.0 Volts
6.1.3.11		30.6			+29.5-31.5 Volts
6.1.3.12		✓			≤ +0.5 Volts
6.1.3.13		30.0			+29-31 Volts
6.1.3.14		37.1			+36.0-38.0 Volts
6.1.3.15		41.23			+40-46 Volts
6.1.3.16		✓			0-0.1 Amperes
6.1.3.17		✓			≥ 5.0 Amperes
6.1.3.18		570			450-650 Ohms
6.1.3.19		660			500-750 Ohms
6.1.4.1		28.2			-27-34 Volts
6.1.4.2		✓			0-0.1 Amperes
6.1.4.3		7.9			6-10 Amperes
6.1.4.4		✓			0-0.1 Amperes
6.1.4.5		7.9			6-10 Amperes
6.1.4.6		7.9			6-10 Amperes
6.1.4.7		✓			0-0.1 Amperes
6.1.4.8		✓			≥ 5.0 Amperes
6.1.4.9		4.7			3-5 Amperes
6.1.4.10		38.1			-37.5-39.0 Volts

UNIT #3, SERIAL NO. 26269

EMPS252 TEST RECORD FORM cont'd.

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.4.11		30.6			-29.5-31.5 Volts
6.1.4.12		✓			≤ -0.5 Volts
6.1.4.13		30.1			-29-31 Volts
6.1.4.14		36.9			-36.0-38.0 Volts
6.1.4.15		41.2			-40-46 Volts
6.1.4.16		✓			0-0.1 Amperes
6.1.4.17		✓			≥ 5.0 Amperes
6.1.4.18		520			450-650 Ohms
6.1.4.19		620			500-750 Ohms
6.1.5.2		13.8			12.1-14.7 Seconds
6.1.5.3		1.34			1.21-1.47 Seconds
6.1.5.4		✓			≤ 5%
6.1.5.6		14.5			12.1-14.7 Seconds
6.1.5.7		1.36			1.21-1.47 Seconds
6.1.5.8		6.2			≤ 5%
6.1.5.10	X	45.2	X	X	30-50 MS
6.1.5.11	X	5818	X	X	5400-5900 p.f.s.
6.1.5.12		4.99			+4.8-5.1 Volts
6.1.5.13		✓			0-0.1 Amperes
6.1.5.14		4.49			+4.35-4.65 Volts
6.1.6.2		14.4			12.1-14.7 Seconds
6.1.6.3		1.36			1.21-1.47 Seconds
6.1.6.4		5.5			≤ 5%
6.1.6.6		12.9			12.1-14.7 Seconds
6.1.6.7		1.33			1.21-1.47 Seconds
6.1.6.8		✓			≤ 5%
6.1.6.10	X	40.9	X	X	30-50MS
6.1.6.11	X	5770	X	X	5400-5900 p.f.s.
6.1.6.12		5.01			+4.8-5.1 Volts
6.1.6.13		✓			0-0.1 Amperes
6.1.6.14		4.48			+4.35-4.65 Volts

UNIT #3, SERIAL NO. 26269

EMPS252 TEST RECORD FORM cont'd.

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.7.2		✓			Relay Closed
6.1.7.3		4.5			3-7 Seconds, Open
6.1.7.4		24.12			+23-25 Volts
6.1.7.5		✓			Relay Open
6.1.7.6		25.1			+24-26 Volts
6.1.8.2	X	7.5:1	X	X	7.3-7.7:1
6.1.8.3	X	7.5:1	X	X	7.3-7.7:1
6.1.8.5	X	7.5:1	X	X	7.3-7.7:1
6.1.8.6	X	7.5:1	X	X	7.3-7.7:1

-16-

Figure 1

Positive Battery Current Sensor

Unit Serial No. 26269





Figure 2

Negative Battery Current Sensor

Unit Serial No. 26269

11-36

POHWS



UNIT #3


-18-

26269

Figure 3

Positive T.R. Current Sensor

Unit Serial No.




-19-

26269

Figure 4

Negative T.R. Current Sensor


Unit Serial No.



26269
Unit Serial No.

Figure 5

Positive Battery Temperature Sensor



IT-39

Figure 6 \


Negative Battery Temperature Sensor

Unit Serial No

UNIT #3

VOLTS

04-11



Unit No. 1

EMPS252 TEST RECORD FORM

SERIAL NO. 26270

Date 3-5-69

Technician JEL

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.3.1		28.5			+27-34 Volts
6.1.3.2		✓			0-0.1 Amperes
6.1.3.3		8.6			6-10 Amperes
6.1.3.4		✓			0-0.1 Amperes
6.1.3.5		8.6			6-10 Amperes
6.1.3.6		8.6			6-10 Amperes
6.1.3.7		✓			0-0.1 Amperes
6.1.3.8		5.5			≥ 5.0 Amperes
6.1.3.9		4.4			3-5 Amperes
6.1.3.10		38.1			+37.5-39.0 Volts
6.1.3.11		30.6			+29.5-31.5 Volts
6.1.3.12		✓			± 0.5 Volts
6.1.3.13		29.9			+29-31 Volts
6.1.3.14		36.8			+36.0-38.0 Volts
6.1.3.15		41.3			+40-46 Volts
6.1.3.16		✓			0-0.1 Amperes
6.1.3.17		5.5			≥ 5.0 Amperes
6.1.3.18		540			450-650 Ohms
6.1.3.19		630			500-750 Ohms
6.1.4.1		28.0			-27-34 Volts
6.1.4.2		✓			0-0.1 Amperes
6.1.4.3		8.2			6-10 Amperes
6.1.4.4		✓			0-0.1 Amperes
6.1.4.5		8.2			6-10 Amperes
6.1.4.6		8.2			6-10 Amperes
6.1.4.7		✓			0-0.1 Amperes
6.1.4.8		5.6			≥ 5.0 Amperes
6.1.4.9		4.3			3-5 Amperes
6.1.4.10		38.2			-37.5-39.0 Volts

EMPS252 TEST RECORD FORM (cont'd)

SERIAL NO. 26270

Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.4.11		30.5			-29.5-31.5 Volts
6.1.4.12		✓			≤ -0.5 Volts
6.1.4.13		30.1			-29-31 Volts
6.1.4.14		36.9			-36.0-38.0 Volts
6.1.4.15		41.4			-40-46 Volts
6.1.4.16		✓			0-0.1 Amperes
6.1.4.17		5.6			≥ 5.0 Amperes
6.1.4.18		530			450-650 Ohms
6.1.4.19		630			500-750 Ohms
6.1.5.2		13.4			12.1-14.7 Seconds
6.1.5.3		1.36			1.21-1.47 Seconds
6.1.5.4		✓			± 5%
6.1.5.6		14.1			12.1-14.7 Seconds
6.1.5.7		1.35			1.21-1.47 Seconds
6.1.5.8		✓			± 5%
6.1.5.10	X	40.7	X	X	30-50 MS
6.1.5.11	X	5798	X	X	5400-5900 p.f.s.
6.1.5.12		5.00			+4.8-5.1 Volts
6.1.5.13		✓			0-0.1 Amperes
6.1.5.14		4.51			+4.35-4.65 Volts
6.1.6.2		13.4			12.1-14.7 Seconds
6.1.6.3		1.35			1.21-1.47 Seconds
6.1.6.4		✓			± 5%
6.1.6.6		13.5			12.1-14.7 Seconds
6.1.6.7		1.35			1.21-1.47 Seconds
6.1.6.8		✓			± 5%
6.1.6.10	X	40.6	X	X	30-50MS
6.1.6.11	X	5785	X	X	5400-5900 p.f.s.
6.1.6.12		4.99			+4.8-5.1 Volts
6.1.6.13		✓			0-0.1 Amperes
6.1.6.14		4.49			+4.35-4.65 Volts

EMPS252 TEST RECORD FORM (cont'd).

SERIAL NO. 26270


Test Procedure Para.	0°F	+70°F	+120°F	+160°F	Range
6.1.7.2		✓			Relay Closed
6.1.7.3		5			3-7 Seconds, Open
6.1.7.4		23.98			+23-25 Volts
6.1.7.5		✓			Relay Open
6.1.7.6		24.95			+24-26 Volts
6.1.8.2	X	7.5:1	X	X	7.3-7.7:1
6.1.8.3	X	7.5:1	X	X	7.3-7.7:1
6.1.8.5	X	7.5:1	X	X	7.3-7.7:1
6.1.8.6	X	7.5:1	X	X	7.3-7.7:1

Figure 1

Positive Battery Current Sensor

Unit Serial No. 26270

UNIT No. 4



VOLTS

II-44


AMPERES

-17-

Figure 2

Negative Battery Current Sensor

Unit Serial No. 26270.



-18-

Figure 3

Positive T.R. Current Sensor

Unit Serial No. 26270





Figure 4

Negative T.R. Current Sensor

Unit Serial No. 26270



-20-

Figure 5

Positive Battery Temperature Sensor

26270
Unit Serial No.





Figure 6

Negative Battery Temperature Sensor

Unit Serial No. 26270

VOLTS

64-II



APPENDIX III

THERMAL TEST REPORT

THERMAL TEST REPORT
EMPS252 DC POWER SUPPLY

PURPOSE: To determine maximum operating temperatures of certain significant heat dissipating components within the EMPS252 DC Power Supply.

METHOD: Maximum temperatures were measured while operating the unit in a temperature controlled oven.

PROCEDURE: Thermocouples were installed on major heat dissipating components and on the baseplate mounting flange. The unit was installed with 1/4 - 28 bolts torqued to 85 - 90 inch pounds on a one inch thick, finned aluminum heat sink plate. A styrofoam insulating box enclosed the unit to minimize radiation and convection heat losses. The unit was placed in a Bemco temperature controlled oven and operated at full electrical load while controlling oven temperature to maintain the heat sink at 155°F. This was to simulate a coolant fluid temperature of 150°F and a thermal conductance of 300 BTU/HrFt²°F between the coolant and the coldplate surface. Thermocouple outputs were recorded on a Honeywell Brown Elektronik millivolt recorder.

RESULTS: The maximum observed temperatures are tabulated in the attached Thermal Test Summary. All temperatures are well below their reliable operating limit with the exception of the power transformer, T302. A temperature in excess of 300°F was measured on the core of T302. While this is not detrimental to the core itself it could have an adverse effect on adjacent circuitry.

DISCUSSION: Visual examination of T302 revealed several areas of poor thermal contact. The varnish dip coating on the transformer prevents good contact to the aluminum mounting bracket. Irregularities in the core prevent firm contact between the core and the baseplate of the unit. Since these thermal deficiencies are somewhat inherent in the transformer construction, improvement in heat transfer must be accomplished by other means. A high thermal conductivity epoxy could be applied at the base of the transformer to fill the gap between core and unit baseplate and at the side of the transformer to provide an additional heat transfer path to the vertical mounting bracket that is brazed to the baseplate. In addition, the inside of the cover could be painted flat black to increase radiation heat losses from the transformer.

CONCLUSIONS: The DC Power Supply meets the specified requirements. With minor changes, the thermal design of the EMPS252 DC Power Supply will be even further improved.

EMPS252 DC POWER SUPPLY
THERMAL TEST SUMMARY

THERMOCOUPLE LOCATION	MAXIMUM OBSERVED TEMPERATURE °F
CR 323	173
CR 343	184
CR 346	185
CR 357	190
Q 1	170
Q 9	195
Q 15	207
Q 212	185
Q 305	170
Q 314	172
Q 321	169
R 323	174
R 340	169
T 302 MTG BRKT	234
T 302 CORE	325
BASEPLATE	157
COLDPLATE*	155

* ACTUAL COLDPLATE TEMPERATURE DURING TEST REACHED 169°F. TEMPERATURES LISTED HAVE BEEN ADJUSTED TO CORRESPOND WITH 155°F COLDPLATE SURFACE.

EMPS252 DC POWER SUPPLY
SUPPLEMENTARY THERMAL TEST

AN ADDITIONAL THERMAL TEST WAS PERFORMED TO DETERMINE THE AMOUNT OF IMPROVEMENT ACHIEVED BY ADDING THERMAL BOND 312 EPOXY FILLING BETWEEN POWER TRANSFORMER T 302 and THE UNIT CASE.

T 302 MTG BRKT TEMPERATURE CHANGED FROM 234 to 218°F
T 302 CORE TEMPERATURE CHANGED FROM 325 to 311°F

BRAYTON CYCLE CONTRACTS

BASIC FINAL REPORT DISTRIBUTION LISTS

NASA Lewis Research Center
21000 Brookpark Road
Cleveland, Ohio 44135
Attention.

Contract Manager (5 + reproducible)
Mail Stop 500-201

Brayton Project Office (25) P. A. Thollot (1)
Mail Stop 500-201 Mail Stop 500-201

H. O. Slone (1) A. S. Valerino (1)
Mail Stop 500-201 Mail Stop 500-202

D. R. Packe (1) H. A. Shumaker (1)
Mail Stop 500-201 Mail Stop 500-202

R. E. English (1) W. L. Stewart (1)
Mail Stop 500-201 Mail Stop 77-2

B. Lubarsky (1) Library (2)
Mail Stop 3-3 Mail Stop 60-3

J. E. Dilley (1) Report Control Office (1)
Mail Stop 500-309 Mail Stop 5-5

D. G. Beremand (1) Reliability & Quality Assurance Office (1)
Mail Stop 500-201 Mail Stop 500-111

W. T. Wintucky (1) Technology Utilization Office (1)
Mail Stop 500-201 Mail Stop 3-19

V. Hlavin (1)
Mail Stop 3-14

NASA Lewis Research Center
Plum Brook Station
Taylor Road
Sandusky, Ohio 44870
Attention: J. C. Nettles (2)
Mail Stop 1441-1

National Aeronautics & Space Adm.
Washington, D. C. 20546
Attention: P. R. Miller (1)
Code RNP
H. D. Rothen (1)
Code RNP

NASA Scientific & Technical Information Facility
 Post Office Box 5700
 College Park, Maryland 20740
 Attention Acquisitions Branch (SQT-34054) (1 + reproducible)

NASA Ames Research Center
 Moffett Field, California 94035
 Attention. Library (1)

NASA Flight Research Center
 Post Office Box 273
 Edwards, California 93523
 Attention. Library (1)

NASA Goddard Space Flight Center
 Greenbelt, Maryland 20771
 Attention. Library (1)

Jet Propulsion Laboratory
 4800 Oak Grove Drive
 Pasadena, California 91103
 Attention: Library (1)

NASA Langley Research Center
 Langley Station
 Hampton, Virginia 23365
 AttentionL Library (1)

NASA Manned Spacecraft Center
 Houston, Texas 77058
 Attention: Library (1)
 A. Redding - EP-5 (1)

NASA Marshall Space Flight Center
 Marshall Space Flight Center, Ala.
 35812
 Attention. Library (1)

Aerojet-General Corporation
 1100 West Hollyvale
 Azusa, California 91702
 Attention: Library (1)

Aerospace Corporation
 Post Office Box 95085
 Los Angeles, California 91745
 Attention Library (1)

A1Research Manufacturing Co.
 402 South 36 Street
 Phoenix, Arizona 85034
 Attention Library (1)
 Lyle Six (1)

A1Research Manufacturing Co.
 9851 Sepulveda Boulevard
 Los Angeles, California 90009
 Attention. Library (1)

A1Research Manufacturing Co.
 2525 W. 190 Street
 Torrance, California 90509
 Attention Library (1)

Battelle Memorial Institute
 505 King Avenue
 Columbus, Ohio 43201
 Attention Library (1)

Bendix Research Labs Division
 Detroit, Michigan 48232
 Attention Library (1)

Boeing Company
 Aerospace Division
 Post Office Box 3707
 Seattle, Washington 98124
 Attention. Library (1)

Borg-Warner Corporation
Pesco Products Division
24700 North Miles Road
Bedford, Ohio 44146
Attention. Library (1)

Bureau of Naval Weapons
Department of the Navy
Washington, D. C. 20025
Attention. Code RAPP (1)

Continental Aviation &
Engineering Corp.
12700 Kercheval Avenue
Detroit, Michigan 48215
Attention Library (1)

Curtiss-Wright Corporation
Wright Aero Division
Main & Passaic Streets
Woodridge, New Jersey 07075
Attention Library (1)

General Dynamics Corporation
16501 Brookpark Road
Cleveland, Ohio 44142
Attention Library (1)

General Electric Company
Mechanical Technology Laboratory
R & D Center
Schenectady, New York 12301
Attention Library (1)

General Electric Company
Space Division
Cincinnati, Ohio 45215
Attention. Library (1)

General Electric Company
Re-entry & Environmental Sys. Div.
3198 Chestnut Street
Philadelphia, Pa. 19104
Attention: Library (1)

General Motors Corporation
Indianapolis, Indiana 46206
Attention, Library (1)

Hughes Aircraft Corporation
Centinda & Teale Avenue
Culver City, California 90230
Attention Library (1)

Institute for Defense Analyses
400 Army-Navy Drive
Arlington, Virginia 22202
Attention Library (1)

Lear Siegler, Inc.
3171 S Bundy Drive
Santa Monica, California 90406
Attention. Library (1)

Lockheed Missiles & Space Co.
Post Office Box 504
Sunnyvale, California 94088
Attention Library (1)

McDonnell Douglas Astronautics Co.
5301 Bolsa Avenue
Huntington Beach, California 92647
Attention Library (1)

McDonnell Douglas Astronautics Co.
3000 Ocean Park Boulevard
Santa Monica, California 90406
Attention Library (1)

Massachusetts Institute of Technology
Cambridge, Massachusetts 02139
Attention: Library (1)

Mechanical Technology Incorporated
968 Albany-Shaker Road
Latham, New York 12110
Attention: Library (1)

North American Rockwell Corp.
Space Division
12214 Lakewood Boulevard
Downey, California 90241
Attention: Library (1)

Northern Research &
Engineering Co.
219 Vassar Street
Cambridge, Massachusetts 02139
Attention: Library (1)

Power Information Center
University of Pennsylvania
3401 Market Street, Room 2107
Philadelphia, Pennsylvania 19104

Solar
Div. of International Harvester
2200 Pacific Highway
San Diego, California 92112
Attention: Library (1)

Space Systems Division
Los Angeles Air Force Station
Los Angeles, California 90045
Attention: Library (1)

Sunstrand Denver
2480 West 70 Avenue
Denver, Colorado 80221
Attention: Library (1)

TRW Accessories Division
23555 Euclid Avenue
Cleveland, Ohio 44117
Attention: Library (1)

TRW Systems
One Space Park
Redondo Beach, California 90278
Attention: Library (1)

U. S. Army Engineer R & D Labs
Gas Turbine Test Facility
Fort Belvoir, Virginia 22060
Attention W. Crim

United Aircraft Corporation
Pratt & Whitney Aircraft Div.
400 Main Street
East Hartford, Conn. 06108
Attention Library (1)

United Aircraft Research Lab
East Hartford, Conn. 06108
Attention Library (1)

Westinghouse Electric Corp.
Astronuclear Laboratory
Post Office Box 10864
Pittsburgh, Pennsylvania 15236-0064
Attention: Library (1)

Williams Research
Walled Lake, Michigan 48088
Attention: Library (1)